

Iroquois Wastewater Treatment System

Sewage Works #120000159

Annual Report

Prepared for: Municipality of South Dundas

Reporting Period of January 1st – December 31st 2019

Issued: March 19, 2020

Revision: 0

Table of Contents

Operations and Compliance Reliability Indices	1
System Process Description	1
Wastewater System Flows.....	2
Raw Flows	2
Effluent Flow.....	3
Effluent Quality Assurance or Control Measures.....	3
Effluent Quality	3
Carbonaceous Biochemical Oxygen Demand (5-Day)	4
Total Suspended Solids.....	5
Total Phosphorus.....	6
Total Ammonia Nitrogen	7
pH.....	8
E. Coli	8
Acute Lethality.....	9
Operating Issues	9
Maintenance	9
Flow Meter Calibration and Maintenance	9
Maintenance Summary	9
Notice of Modifications	9
Sludge Generation	10
Summary of Complaints.....	10
Summary of Abnormal Discharge Events	10
Bypass/Overflow.....	10
Spills.....	10
Performance Assessment Reports	A
Flow Meter Calibration Reports.....	B

Operations and Compliance Reliability Indices

Compliance Event	# of Events
Ministry of Environment Inspections	0
Ministry of Labour Inspections	0
Non-Compliance	0
Spills/Overflows/Bypasses	0
Sewer Main Blockages	0

System Process Description

Iroquois's sewage collection system is a gravity fed sanitary sewage collection system. There are two pumping stations which pump wastewater from the collection system to the wastewater treatment facility.

The Iroquois Wastewater Treatment Plant (WWTP) is a Class II wastewater treatment facility owned and operated by the Municipality of South Dundas. Raw sewage is pumped to the WWTP by the plant pumping station which is equipped with three submersible pumps. From the pumping station, wastewater passes through the inlet works, including mechanically cleaned fine screens and a grit removal and disposal system. Aluminum Sulphate is added to assist in phosphorous removal. The wastewater then moves through either of two parallel Sequencing Batch Reactors (SBRs) equipped with individual aeration systems, mixers, decanters and sludge removal pumps. Effluent decanted from the SBRs is treated by UV disinfection and subsequently passes through an outfall pipe to the St. Lawrence River.


Sludge removed from the SBRs is transferred to a waste activated sludge tank. From the tank, the sludge enters a rotary drum thickener. Polymer is added to assist with the thickening process. Thickened sludge is pumped to an Autothermal Thermophilic Aerobic Digestion (ATAD) system for stabilization. The ATAD system is equipped with an off-gas scrubber and biofilter to provide odour control. The digested sludge is then pumped to one of three biosolids storage tanks. From the storage tanks, biosolids are hauled off site to be utilized as soil conditioner.

Wastewater System Flows


The hydraulic flows reaching the treatment facility in 2019 averaged 1,979 m³/day which represents 60% of the 3,300 m³/day design. Please see the Performance Assessment Reports attached in Appendix A for details.

Raw Flows

2019 Raw Flows:



Annual Raw Flow Comparison:



Effluent Flow

A total of 710,025 m³ of effluent was discharged from Iroquois' wastewater treatment facility in 2019.

Effluent Quality Assurance or Control Measures

Effluent control measures include in-house sampling and testing for operational parameters. In-house testing provides real time results which are then used to enhance process and operational performance. Samples are collected by the Municipality of South Dundas' competent and licensed staff using approved methods and protocols for sampling including those specified in the Ministry's Procedure F-10-1, "Procedures for Sampling and Analysis Requirements for Municipal and Private Sewage Treatment Works", the Ministry's publication, "Protocol for the Sampling and Analysis of Industrial/Municipal Wastewater" and the publication, "Standard Methods for the Examination of Water and Wastewater".

Effluent samples collected during the reporting period were submitted to Caduceon laboratory in Ottawa for analysis, with the exception of pH, temperature and unionized ammonia. Caduceon is accredited by the Canadian Association for Laboratory Accreditation (CALA). Accredited labs must meet strict provincial guidelines including an extensive quality assurance/quality control program. By choosing this laboratory, the Municipality of South Dundas is ensuring appropriate control measures are undertaken during sample analysis.

The pH and temperature parameters were analyzed in the field at the time of sample collection by certified operators to ensure accuracy and precision of the results obtained. Un-ionized ammonia was calculated using the total ammonia nitrogen concentration, pH and temperature as required by the facility's Certificate of Approval.

Effluent Quality


The monthly average concentrations of carbonaceous biochemical oxygen demand (CBOD₅), total suspended solids (TSS), total phosphorus (TP) and total ammonia nitrogen (TAN) remained below the effluent objectives and limits outlined in the facility's Certificate of Approval during 2019. The geometric mean density of E. coli in the effluent also remained below the ECA limit and objective in 2019. In addition the effluent pH remained within the limits and objectives throughout the year.

Effluent results from the WWTP for 2019 are tabulated below.


Carbonaceous Biochemical Oxygen Demand (5-Day)

Monthly Average	C of A Limit	C of A Objective	Exceedance
Concentration (mg/L)	25	15	No
Loading (kg/d)	82.5	n/a	No

CBOD₅ Effluent Monthly Average Concentrations:




CBOD₅ Monthly Average Loading:




Total Suspended Solids

Monthly Average	C of A Limit	C of A Objective	Exceedance
Concentration (mg/L)	25	15	No
Loading (kg/d)	82.5	n/a	No

TSS Effluent Monthly Average Concentrations:




TSS Monthly Average Loading:




Total Phosphorus

Monthly Average	C of A Limit	C of A Objective	Exceedance
Concentration (mg/L)	1.0	0.6	No
Loading (kg/d)	3.3	n/a	No

TP Effluent Monthly Average Concentrations:




TP Monthly Average Loading:




Total Ammonia Nitrogen

Monthly Average	Discharge Period	C of A Limit	C of A Objective	Exceedance
Concentration (mg/L)	Jun. 1 – Sept. 30	10	5	No
Loading (kg/d)		33	n/a	No
Concentration (mg/L)	Oct. 1 – May 31	15	7	No
Loading (kg/d)		49.5	n/a	No

TAN Effluent Monthly Average Concentrations:




TAN Monthly Average Loading:



pH


Reporting Period	C of A Limit	C of A Objective	Exceedance
All results	6.0 – 9.5	6.5 – 9.5	No

Monthly Minimum and Maximum pH Results:

**E. Coli**

Monthly Average	C of A Limit	C of A Objective	Exceedance
Geometric Mean Density	200	150	No

E. Coli Monthly Geometric Mean Density (cfu/100 mL):



Acute Lethality

One sample was collected in 2019 and tested for acute lethality to Rainbow Trout and Daphnia Magna. Results are displayed as % mortality. An adverse result is indicated by a > 50% mortality rate.

Date	Rainbow Trout	Daphnia Magna
01-29-2019	0 %	0 %

Operating Issues

The maximum recorded flows during the months of January, March, April, October, November and December exceeded the average day design for the Iroquois WWTP. Based on a historical review of flows, it appears this system is impacted by inflow and infiltration.

Maintenance

Flow Meter Calibration and Maintenance

Copies of the flow meter calibration certificates for 2019 are attached in Appendix B.

Maintenance Summary

Description
<ul style="list-style-type: none"> - ISI reset hour counter in PLC and disconnected bypass - reinstalled grit motor and coupling unit - replaced motor/pump coupling on booster pump - replaced batteries in UPS cabinet - changed belt on air exhaust unit in blower room - serviced jet pump - replaced ORP probe - replaced self greasers - performed maintenance to alum pump - changed hydraulic fluid in UV system - performed maintenance on UV system

Notice of Modifications

Date	Process	Modification	Status
None to report.			

Sludge Generation

In 2019, a total of 458 m³ of liquid sludge was removed from Iroquois' WWTP and transported to a Waste Transfer Station by Terrapure Environmental where it was mixed with other materials (ECA #A710174). It is anticipated that approximately the same volume of sludge will be generated in 2020.

Summary of Complaints

There were no complaints documented during the reporting period.

Summary of Abnormal Discharge Events

Bypass/Overflow

No bypasses or overflows occurred during the reporting period.

Spills

No spills occurred during the reporting period.

Appendix A

Performance Assessment Reports

IROQUOIS WWTP

PERFORMANCE ASSESSMENT REPORT

**MUNICIPALITY: SOUTH DUNDAS
PROJECT: IROQUOIS WWTP
WORKS NUM.: 120000159
DESCRIPTION: TWO SEQUENTIAL**

YEAR: 2019
WATER COURSE: ST. LAWRENCE
DESIGN CAPACITY: $3,300 \text{ m}^3/\text{d}$

2019 - IROQUOIS WWTP EFFLUENT SAMPLING MONTHLY AVERAGES

MONTH	DATE	CBOD (mg/L)	TSS (mg/L)	TP (mg/L)	NH ₃ (mg/L)	E. Coli (CFU/100ml)
January	01/03/2019	< 3	< 3	0.19	0.04	< 2
	01/10/2019	< 3	< 3	0.25	0.02	< 2
	01/17/2019	< 3	< 3	0.23	0.12	< 2
	01/24/2019	< 3	12	0.24	0.1	< 2
	01/31/2019	5	< 3	0.21	0.12	< 2
	Monthly Average	3.4	4.8	0.22	0.08	2
February	Compliant?	YES	YES	YES	YES	YES
	02/07/2019	< 3	6	0.21	0.07	< 2
	02/14/2019	< 3	< 3	0.21	0.05	< 2
	02/21/2019	< 3	7	0.18	0.09	< 2
	02/28/2019	4	5	0.2	0.11	< 2
	Monthly Average	3.3	5.3	0.20	0.08	2
March	Compliant?	YES	YES	YES	YES	YES
	03/07/2019	< 3	3	0.2	0.06	< 2
	03/14/2019	< 3	< 3	0.15	0.07	< 2
	03/21/2019	< 3	3	0.14	0.62	< 2
	03/28/2019	< 3	3	0.2	0.06	< 2
	Monthly Average	3.0	3.0	0.17	0.20	2
April	Compliant?	YES	YES	YES	YES	YES
	04/04/2019	< 3	< 3	0.26	0.06	< 2
	04/11/2019	< 3	7	0.21	0.08	< 2
	04/17/2019	< 3	< 3	0.43	0.08	< 2
	04/25/2019	< 3	< 3	0.19	0.07	< 2
	Monthly Average	3.0	4.0	0.27	0.07	2
May	Compliant?	YES	YES	YES	YES	YES
	05/02/2019	< 3	< 3	0.22	0.11	< 2
	05/09/2019	< 3	< 3	0.25	0.1	< 2
	05/16/2019	< 3	< 3	0.26	0.06	< 2
	05/23/2019	< 3	< 3	0.33	0.08	< 2
	05/30/2019	< 3	3	0.4	0.06	< 2
June	Monthly Average	3.0	3.0	0.29	0.08	2
	Compliant?	YES	YES	YES	YES	YES
	06/06/2019	< 3	5	0.38	0.09	< 2
	06/13/2019	< 3	< 3	0.39	0.08	< 2
	06/20/2019	< 3	< 3	0.32	0.12	< 2
	06/27/2019	< 3	5	0.55	0.06	< 2
July	Monthly Average	3.0	4.0	0.41	0.09	2
	Compliant?	YES	YES	YES	YES	YES
	07/04/2019	< 3	4	0.56	0.11	< 2
	07/11/2019	< 3	< 3	0.41	0.07	< 2
	07/18/2019	< 3	3	0.33	0.07	< 2
	07/25/2019	< 3	< 3	0.22	0.08	< 2
August	Monthly Average	3.0	3.3	0.38	0.08	2
	Compliant?	YES	YES	YES	YES	YES
	08/01/2019	52	34	0.2	0.05	2
	08/08/2019	< 3	3	0.17	0.12	< 2
	08/15/2019	< 3	3	0.21	0.08	< 2
	08/22/2019	< 3	< 3	0.24	0.08	< 2
September	08/29/2019	< 3	< 3	0.28	0.11	< 2
	Monthly Average	12.8	9.2	0.22	0.09	2
	Compliant?	YES	YES	YES	YES	YES
	09/05/2019	< 3	< 3	0.26	0.06	< 2
	09/12/2019	< 3	5	0.39	0.06	< 2
	09/19/2019	< 3	< 3	0.35	0.09	< 2
October	09/26/2019	< 3	4	0.33	0.10	4
	Monthly Average	3.0	3.75	0.33	0.08	2
	Compliant?	YES	YES	YES	YES	YES
	10/03/2019	< 3	< 3	0.29	0.12	< 2
	10/10/2019	< 3	< 3	0.38	0.12	< 2
	10/17/2019	< 3	< 3	0.26	0.11	< 2
November	10/24/2019	< 3	4	0.23	0.08	< 2
	10/31/2019	< 3	< 3	0.26	0.08	10
	Monthly Average	3	3.2	0.28	0.10	2
	Compliant?	YES	YES	YES	YES	YES
	11/07/2019	< 3	6	0.25	0.08	< 2
	11/14/2019	< 3	5	0.33	0.08	< 2
December	11/21/2019	< 3	3	0.39	0.09	< 2
	11/28/2019	< 3	8	0.35	0.06	< 2
	Monthly Average	3.0	5.5	0.33	0.08	2
	Compliant?	YES	YES	YES	YES	YES
	12/05/2019	< 3	9	0.33	0.05	< 2
	12/12/2019	< 3	< 3	0.3	0.1	2
	12/19/2019	< 3	3	0.31	0.06	0
	12/23/2019	< 3	< 3	0.51	0.06	2
	Monthly Average	3.0	4.5	0.36	0.07	0
	Compliant?	YES	YES	YES	YES	YES

2019 - IROQUOIS WWTP LOADING CALCULATIONS

MONTH	Total Effluent Flow (m ³)		BOD	TSS	TP	NH ₃
January	51,714	Monthly Average (mg/L)	3.4	4.8	0.2	0.08
		Loading (kg/d)	5.67	8.01	0.37	0.13
		Compliant?	YES	YES	YES	YES
February	41,700	Monthly Average (mg/L)	3.3	5.25	0.20	0.08
		Loading (kg/d)	4.37	7.06	0.27	0.11
		Compliant?	YES	YES	YES	YES
March	107,041	Monthly Average (mg/L)	3.0	3.0	0.17	0.20
		Loading (kg/d)	10.36	10.36	0.60	0.70
		Compliant?	YES	YES	YES	YES
April	122,802	Monthly Average (mg/L)	3.0	4	0.27	0.07
		Loading (kg/d)	11.88	15.85	1.08	0.29
		Compliant?	YES	YES	YES	YES
May	80,057	Monthly Average (mg/L)	3.0	3	0.29	0.082
		Loading (kg/d)	7.75	7.75	0.75	0.21
		Compliant?	YES	YES	YES	YES
June	54,091	Monthly Average (mg/L)	3.0	4	0.41	0.09
		Loading (kg/d)	5.23	6.98	0.72	0.15
		Compliant?	YES	YES	YES	YES
July	30,295	Monthly Average (mg/L)	3.0	3.3	0.38	0.08
		Loading (kg/d)	2.93	3.18	0.37	0.08
		Compliant?	YES	YES	YES	YES
August	20,329	Monthly Average (mg/L)	12.8	9.2	0.22	0.09
		Loading (kg/d)	8.39	6.03	0.14	0.06
		Compliant?	YES	YES	YES	YES
September	23,655	Monthly Average (mg/L)	3.0	3.75	0.33	0.08
		Loading (kg/d)	2.29	2.86	0.25	0.06
		Compliant?	YES	YES	YES	YES
October	41,531	Monthly Average (mg/L)	3.0	3.2	0.28	0.10
		Loading (kg/d)	4.02	4.29	0.38	0.14
		Compliant?	YES	YES	YES	YES
November	77,597	Monthly Average (mg/L)	3.0	5.5	0.33	0.08
		Loading (kg/d)	7.51	13.77	0.83	0.19
		Compliant?	YES	YES	YES	YES
December	59,212	Monthly Average (mg/L)	3.0	4.5	0.36	0.07
		Loading (kg/d)	5.73	8.60	0.69	0.13
		Compliant?	YES	YES	YES	YES

2019 - IROQUOIS WWTP EFFLUENT UN-IONIZED AMMONIA

Sample Date	Sample Temperature °C	Sample Temp. Kelvin	Dissociation Constant pK _a	Effluent Sample pH on-site	Fraction of Un-ionized Ammonia	Total Ammonia (mg/L) (NH ₃ + NH ₄ as N)	Un-ionized Ammonia (mg/L)
01/03/2019	10.0	283.15	9.73	8.0	0.0182	0.04	0.0007
01/10/2019	10.9	284.05	9.70	8.1	0.0245	0.02	0.0005
01/17/2019	10.2	283.35	9.72	8.1	0.0232	0.12	0.0028
01/24/2019	9.7	282.85	9.74	8.0	0.0178	0.1	0.0018
01/31/2019	9.8	282.95	9.74	8.3	0.0352	0.12	0.0042
02/07/2019	10.1	283.25	9.73	7.8	0.0117	0.07	0.0008
02/14/2019	9.6	282.75	9.75	8.2	0.0277	0.05	0.0014
02/21/2019	9.4	282.55	9.75	8.2	0.0273	0.09	0.0025
02/28/2019	8.8	281.95	9.77	8.3	0.0326	0.11	0.0036
03/07/2019	8.4	281.55	9.79	8.4	0.0395	0.06	0.0024
03/14/2019	9.6	282.75	9.75	8.2	0.0277	0.07	0.0019
03/21/2019	8.3	281.45	9.79	8.3	0.0314	0.62	0.0194
03/28/2019	7.7	280.85	9.81	8.1	0.0191	0.06	0.0011
04/04/2019	7.3	280.48	9.82	8.3	0.0291	0.06	0.0017
04/11/2019	7.8	280.95	9.81	8.2	0.0241	0.08	0.0019
04/17/2019	8.6	281.75	9.78	7.5	0.0052	0.08	0.0004
04/25/2019	10.6	283.75	9.71	7.8	0.0121	0.07	0.0008
05/02/2019	11.6	284.75	9.68	8.1	0.0258	0.11	0.0028
05/09/2019	11.2	284.35	9.69	7.8	0.0127	0.1	0.0013
05/16/2019	12.4	285.55	9.65	7.7	0.0111	0.06	0.0007
05/23/2019	13.5	286.65	9.61	7.9	0.0190	0.08	0.0015
05/30/2019	12.3	285.45	9.65	7.7	0.0110	0.06	0.0007
06/06/2019	12.5	285.65	9.65	7.7	0.0112	0.09	0.0010
06/13/2019	13.1	286.25	9.63	7.9	0.0184	0.08	0.0015
06/20/2019	13.3	286.45	9.62	7.6	0.0095	0.12	0.0011
06/27/2019	13.6	286.75	9.61	7.9	0.0191	0.06	0.0011
07/04/2019	13.8	286.95	9.60	7.9	0.0194	0.11	0.0021
07/11/2019	14.1	287.25	9.59	7.8	0.0158	0.07	0.0011
07/18/2019	13.9	287.05	9.60	7.6	0.0099	0.07	0.0007
07/25/2019	14.6	287.75	9.58	7.6	0.0104	0.08	0.0008
08/01/2019	16.8	289.95	9.51	7.5	0.0098	0.05	0.0005
08/08/2019	16.6	289.75	9.51	7.7	0.0152	0.12	0.0018
08/15/2019	16.9	290.05	9.50	7.7	0.0155	0.08	0.0012
08/22/2019	17.1	290.25	9.50	7.7	0.0158	0.08	0.0013
08/29/2019	17.8	290.95	9.47	7.9	0.0260	0.11	0.0029
09/05/2019	17.1	290.25	9.50	7.7	0.0158	0.06	0.0009
09/12/2019	18	291.15	9.47	7.8	0.0211	0.06	0.0013
09/19/2019	18.1	291.25	9.46	7.9	0.0266	0.09	0.0024
09/26/2019	18.1	291.25	9.46	7.9	0.0266	0.1	0.0027
10/10/2019	16.5	289.65	9.52	7.9	0.0237	0.12	0.0028
10/17/2019	16.4	289.55	9.52	8.0	0.0294	0.11	0.0032
10/24/2019	16	289.15	9.53	7.4	0.0079	0.08	0.0006
10/31/2019	15.4	288.55	9.55	7.4	0.0069	0.08	0.0005
11/07/2019	14.1	287.25	9.59	7.4	0.0059	0.08	0.0005
11/14/2019	13.5	286.65	9.61	6.9	0.0019	0.08	0.0002
11/21/2019	13.9	287.05	9.60	7.5	0.0086	0.09	0.0008
11/28/2019	13.3	286.45	9.62	7.7	0.0108	0.06	0.0007
12/05/2019	15.6	288.75	9.54	7.5	0.0084	0.05	0.0004
12/12/2019	14.2	287.35	9.59	7.8	0.0163	0.1	0.0016
12/19/2019	11.7	284.85	9.67	7.7	0.0105	0.06	0.0006
12/23/2019	12.5	285.65	9.65	7.6	0.0093	0.06	0.0006

pK_a = 0.09018 + 2729.92/T, where pK_a is the dissociation constant of ammonia at a given temperature.

T = (K = degrees C + 273.16), where T is the ambient water temperature in Kelvin.

2019 - IROQUOIS WWTP AEROBIC BIOSOLIDS RESULTS

SLUDGE RESULTS		03-Jan-19	07-Feb-19	07-Mar-20	04-Apr-19	02-May-19	06-Jun-19	11-Jul-19	08-Aug-19	05-Sep-19	03-Oct-19	07-Nov-19	05-Dec-19
Ammonia	mg/L	1350	1450	1570	899	1270	981	997	1420	1100	959	1050	1300
Nitrate	mg/L	< 3	< 3	4.4	< 5	< 1	5.9	< 1	2.6	3.7	< 10	< 1	1.8
Ammonia + Nitrate	mg/L	1353	1453	1574	904	1271	987	998	1423	1104	969	1051	1302
Total Phosphorus	mg/L	1880	1730	1460	1360	1580	1130	970	1410	1230	1070	1070	1140
Total Solids	mg/L	38400	56200	44100	43900	72000	38000	82300	38900	35000	26600	32000	33300
Aluminum	mg/L	2350	1570	1580	1990	1940	1970	1720	1540	1110	1090	1260	1410
Arsenic	mg/L	0.20	0.20	0.10	0.20	0.20	0.20	0.2	0.3	0.1	0.1	0.20	0.19
Cadmium	mg/L	0.050	0.040	0.040	< 0.030	0.040	0.040	0.04	0.05	0.030	< 0.03	0.040	0.040
Chromium	mg/L	1.63	0.86	0.86	0.99	1.11	1.55	1.5	2.14	1.03	0.83	0.76	1.10
Cobalt	mg/L	0.19	0.13	0.090	0.12	0.20	0.20	0.22	0.21	0.12	0.06	0.10	0.13
Copper	mg/L	73.00	51.00	53.00	63.50	62.50	67.00	62	79.5	44.3	31.9	47.8	44.90
Lead	mg/L	1.40	1.00	1.00	1.20	1.40	1.80	1.6	1.7	1	0.6	0.90	1.00
Mercury	mg/L	0.02	0.05	0.02	0.01	0.01	0.04	0.057	0.029	0.011	0.016	0.012	0.01
Molybdenum	mg/L	0.49	0.36	0.34	0.49	0.53	0.52	0.56	0.63	0.35	0.26	0.38	0.37
Nickel	mg/L	1.62	1.05	1.13	1.40	1.53	1.69	1.65	1.87	1.05	0.84	0.94	1.10
Selenium	mg/L	0.20	0.10	0.10	0.20	0.20	0.20	0.2	0.2	0.1	0.1	0.10	0.20
Zinc	mg/L	36.0	25.40	24.80	31.0	31.80	29.00	28.4	27	21.9	17.1	24.6	25.90

Appendix B

Flow Meter Calibration Reports

CapitalControls

Electrical/Control Panels – PLC/SCADA Programming – Instrumentation Calibrations

830 Industrial Ave. Ottawa, ON K1G-4B8 Ph. 613 248-1999 Fax: 613 248-1997

5 Iroquois W.P.C.P.

Site Reports August, 2019

CapitalControls

Electrical/Control Panels – PLC/SCADA Programming – Instrumentation Calibrations

830 Industrial Ave. Ottawa, ON K1G-4B8 Ph. 613 248-1999 Fax: 613 248-1997

5.1 FIT-401 Waste Sludge Basin 1:

DTM Version: 3.29.00

Page 1/3

Flowmeter Verification Certificate Transmitter

On-Site	Plant
Orifice	Tag Name
FRCMAG 10 W DN80	1.0381 - 1.0381
Dates line	K-Padur
H107C810300	0
Serial number	Zero point
V1.03.00	
Software Version Transmitter	Software Version I/O-Module
07/28/2019	09:01 AM
Verification date	Verification time

Verification result Transmitter: Passed

Test Item	Result	Applied Limits
Amplifier	Passed	Basis: 0.05 %
Current Output 1	Passed	0.05 mA
Pulse Output 1	Not tested	0 P
Test Sensor	Passed	

FieldCheck Details
230223
Precision number
1.07.06
Software Version
03/2019
Last Calibration Date

Standards Details
8794331
Precision number
1.00.01
Software Version
03/2019
Last Calibration Date

Date: _____ Operator's Sign: _____ Inspector's Sign: _____
Overall results: _____

The achieved test results show that the instrument is completely functional, and the measuring results lie within +/- 1% of the original calibration.
The calibration of the Fieldcheck test system is fully traceable to national standards.

(*) Prerequisite is an additional proof of electrode integrity with a high voltage test.

Endress+Hauser 

CapitalControls

Electrical/Control Panels -- PLC/SCADA Programming – Instrumentation Calibrations

830 Industrial Ave. Ottawa, ON K1G-4B8 Ph. 613 248-1999 Fax: 613 248-1997

Page 2/3

FieldCheck - Result Tab Transmitter

Customer	Plant
Chassis	Test Date
Device type	PROFINET 10V DNI09
Serial number	H107C910869
Software Version Transmitter	V1.43.00
Verification Date	07/22/2019
K-Fader	1.0001 - 1.0001
Zero point	0
Software Version IO-Monitor	V2.00.02
Verification time	02:01 AM

Verification Flow and value (100 % ± 20.103 %
Flow speed 4.00 m/s

Passed / Failed	Test Item	Stand. Signal	Limit Value	Deviation
	Test Transmitter			
✓	Amplifier	1.001% (99%)	1.00 %	-0.01 %
✓		2.011% (10.0%)	1.10 %	0.16 %
✓		10.003% (50.0%)	0.70 %	-0.03 %
✓		20.101% (100%)	0.65 %	-0.03 %
	Current Test 1			
✓		4.000 mA (0%)	0.05 mA	0.020 mA
✓		4.000 mA (5%)	0.05 mA	-0.020 mA
✓		5.000 mA (10.0%)	0.05 mA	-0.022 mA
✓		12.000 mA (30.0%)	0.05 mA	0.002 mA
✓		20.000 mA (100%)	0.05 mA	0.021 mA
—	Pulse Output 1	—	—	—
		Set value	Limits range	Measured value
	Test Summary			
✓	CH1 CH1, 100%	61.000 m/s	13.348...50.000 m/s	43.255 m/s
✓	CH1 CH1, 50.000%		—	—

Legend of symbols

✓	X	—	?	Δ
Passed	Failed	Indicates	Indicates	Indicates

CapitalControls

Electrical/Control Panels – PLC/SCADA Programming – Instrumentation Calibrations

830 Industrial Ave. Ottawa, ON K1G-4B8 Ph. 613 248-1999 Fax: 613 248-1997

Page 3/3

FieldCheck: Parameters Transmitter

Customer	Plant
Order code	---
Device type	PID24AG 16 W D24D9
Serial number	H1070018240
Software Version Transmitter	V1.03.10
Verification date	07/29/2019
	03/01 AM

Current Output	Assign	Current Range	Value 0 mA	Value 20 mA		
Terminal 23/27	VOLUME FLOW	4-20 mA rev	0.0 l/s	50.00 l/s		
Pulse Output	Assign	Pulse Value	Output signal	Pulse width		
Terminal 24/25	VOLUME FLOW	0.008 m3/P	Passive/Positive	100.00 ms		

Actual System Ident.

123.0

CapitalControls

Electrical/Control Panels – PLC/SCADA Programming – Instrumentation Calibrations

830 Industrial Ave. Ottawa, ON K1G-4B8 Ph. 613 248-1999 Fax: 613 248-1997

5.2 FIT-402 Waste Sludge Basin 2:

DTM Version: 3.29.00

Page 1/3

Flowmeter Verification Certificate Transmitter

Customer	Plant
Order code	Tag Name
PRO-MAG 10 W DN90	0.0737 - 0.0737
Device ID#	K-Factor
JAO01316000	0
Serial number	Zero drift
V1.04.00	
Software Version Transmitter	Software Version NO-Mag 00
07/29/2010	08:11 AM
Verification date	Verification Date

Verification result Transmitter: Passed

Test Item	Result	Applied Limit
Analog	Passed	Base: 0.65 %
Current Output 1	Passed	0.05 mA
Pulse Output 1	Not tested	0.P
Test Sensor	Passed	

FieldCheck Details	Stimulus Details
240223	8704351
Production number	Production number
1.07.03	1.07.01
Software Version	Software Version
03/2010	03/2010
Last Calibration Date	Last Calibration Date

Date	Operator's Sign	Inspector's Sign
Overall results:		
The achieved test results show that the instrument is completely functional, and the measuring results lie within +/- 1% of the original calibration. ¹⁾		

1) Frequency is an additional proof of cast-ability with a high voltage test.

Endress+Hauser 
Sensoren & Transmitter für Anwendungen

CapitalControls

Electrical/Control Panels – PLC/SCADA Programming – Instrumentation Calibrations

830 Industrial Ave. Ottawa, ON K1G-4B8 Ph. 613 248-1999 Fax: 613 248-1997

Page 2/3

FieldCheck - Result Tab Transmitter

Customer	Site#
Customer code	Tag Name
Device type	N-Point
PICOLAG 10 VFD 150	0.3737 - 0.3737
Serial number	0
Software Version Transmitter	Software Version 10-120002
Verification date	08/11/2003
	Verification time

Verification Flow end value (100 %) : 20.105 l/s
 Flow speed 4.00 m/s

Passed / Failed	Test Item	Start, Stoped	Limit Value	Deviation
	Test Transmitter			
✓	Amplifier	1.00515 (5%)	1.50 %	-0.23 %
		2.011 l/s (10.0%)	1.10 %	-0.09 %
		10.053 l/s (50.0%)	0.70 %	-0.03 %
		20.105 l/s (100%)	0.65 %	0.03 %
	Current Output 1			
		4.000 mA (0%)	0.05 mA	-0.027 mA
		4.000 mA (5%)	0.05 mA	-0.029 mA
		5.000 mA (10.0%)	0.05 mA	-0.010 mA
		12.000 mA (50.0%)	0.05 mA	-0.022 mA
		20.000 mA (100%)	0.05 mA	-0.022 mA
	Power Output 1	—	—	—
		Start, Value	Limit range	Measuring Value
✓	Test Sensor			
✓	Out Curr. Rate	50.000 ms	13.340, 53.000 0.05	42.001 ms
✓	Out Curr. Stability		—	—

Legend of symbols

X	—	?	
Passed	Failed	not tested	not testable

CapitalControls

Electrical/Control Panels – PLC/SCADA Programming – Instrumentation Calibrations

830 Industrial Ave. Ottawa, ON K1G-4B8 Ph. 613 248-1999 Fax: 613 248-1997

Page 3/3

FieldCheck: Parameters Transmitter

Customer	Plant
Order code	
Device type	FIDURAG 10 W DNI60
Serial number	JM02191E009
Software Version Transmitter	V1.00.00
Validation date	07/22/2013
K-Factor	0.9737 - 0.9737
Zero point	0
Output Scale Value on I/O-Msg64	
Verification time	(2011 AM)

Current Output	Assign	Current Range	Value 0-4mA	Value 20 mA		
Terminal 26/27	VOLUME FLOW	4-20 mA zolliv	0.0 l/s	50.00 l/s		
Pulse Output	Assign	Pulse Value	Output signal	Pulse width		
Terminal 24/25	VOLUME FLOW	0.008 m3/P	Passive/Positive	100.00 ms		

Actual System Ident.

125.0

CapitalControls

Electrical/Control Panels – PLC/SCADA Programming – Instrumentation Calibrations

830 Industrial Ave. Ottawa, ON K1G-4B8 Ph. 613 248-1999 Fax: 613 248-1997

5.3 FIT-305 Raw Sewage Influent Channel 1:

FIELD EQUIPMENT VERIFICATION / CALIBRATION REPORT																								
DATE: July 29 / 2019																								
DESCRIPTION: Iroquois WPCP Raw Sewage Influent Ch#1.		MODEL: OCM III Model: 7ML 1002-0AA05		TAG: FIT-305																				
MANUFACTURER: Siemens		Serial # S/N. PDB/C0010053																						
Client Name: Township of South Dundas. Device Output Signal : 4.00 - 20.0 mA																								
INSTALLATION INSPECTION																								
	DESCRIPTION	FINDINGS				COMMENTS																		
		OK	FIXED	N/A	FAULTY																			
GENERAL																								
1	TAGGING		X			<i>Calibration by means of Simulating Channel Level</i> Milltronics OCM-III Configuration																		
2						Flume Type = Parshall Size = 12"																		
MECHANICAL																								
3	MOUNTING: check for proper fastening, etc.	X				P46 - Zero Head = 175.3498 cm																		
4	ORIENTATION: check for proper angle, etc.)	X				P7 - Max. Head = 44.28499 cm																		
5	POSITION: relative position to other components (ie. for proper flow, blanking distance), etc.	X				P1 Linear Units = cm Flow Units = l/s																		
6						Type = Flow Parshall	Damping = 20%																	
ELECTRICAL																								
7		X				Trending Configuration Sample at 60 min. Intervals																		
8	WIRE TAGGING: (exists and proper wire type)	X																						
9	QUALITY OF CONNECTIONS:	X																						
10	GROUNDING:	X																						
11	SHIELDING: (check if grounded only at PLC end of wire)	X																						
12	CERTIFICATION CSA, ULC:	X																						
SET-UP/CALIBRATION																								
DIGITAL		ADJUSTMENT USING		VERIFIED USING		SETPOINT / RANGE																		
14	SETPOINT ADJUSTMENT	MECHANICAL TYPE			Level Target	0 - 199.5 l/sec																		
		ELECTRONIC TYPE			Fluke 725 calibrator S/N 8759025																			
Configuration Parameters:		Calibration Data Test Tolerance: 5.00% <table border="1" style="width: 100%; border-collapse: collapse;"> <thead> <tr> <th style="width: 25%;">Input Variable</th> <th style="width: 25%;">Transmitter Value.</th> <th style="width: 25%;">Cal. Value</th> <th style="width: 25%;">% Error</th> <th style="width: 10%;">Notes</th> </tr> </thead> <tbody> <tr> <td>(Calibration Jig set to 0.203 m)</td> <td>0.203 m</td> <td>61.04 l/s</td> <td>59.57 l/s</td> <td>0.54 %</td> <td>Passed</td> </tr> <tr> <td>(Calibration Jig set to 0.064 m)</td> <td>0.064 m</td> <td>10.95 l/s</td> <td>9.95 l/s</td> <td>0.50 %</td> <td>Passed</td> </tr> </tbody> </table>						Input Variable	Transmitter Value.	Cal. Value	% Error	Notes	(Calibration Jig set to 0.203 m)	0.203 m	61.04 l/s	59.57 l/s	0.54 %	Passed	(Calibration Jig set to 0.064 m)	0.064 m	10.95 l/s	9.95 l/s	0.50 %	Passed
Input Variable	Transmitter Value.	Cal. Value	% Error	Notes																				
(Calibration Jig set to 0.203 m)	0.203 m	61.04 l/s	59.57 l/s	0.54 %	Passed																			
(Calibration Jig set to 0.064 m)	0.064 m	10.95 l/s	9.95 l/s	0.50 %	Passed																			
Error (% Full Scale) = ((Transmitter Value - Calculated Value) / Full Scale) * 100 = ((61.04-59.57) / 199.5) * 100 = 0.54 % of full scale						Checked By: <i>Tim Stewart</i> Cell: 613 325 9213 Email: tim.stewart@capitalcontrols.ca																		

CapitalControls

Electrical/Control Panels – PLC/SCADA Programming – Instrumentation Calibrations

830 Industrial Ave. Ottawa, ON K1G-4B8 Ph. 613 248-1999 Fax: 613 248-1997

5.4 FIT-306 Raw Sewage Influent Channel 2:

FIELD EQUIPMENT VERIFICATION / CALIBRATION REPORT							DATE: July 29 / 2019
DESCRIPTION: Iroquois WPCP Raw Sewage Influent Ch#2.			MODEL: OCM III Model: 7ML 1002-0AA05			TAG: FIT-306	
MANUFACTURER : Siemens			Serial # S/N. PDB/C0010053				
Client Name: Township of South Dundas.							Device Output Signal : 4.00 - 20.0 mA
INSTALLATION INSPECTION							
	DESCRIPTION	FINDINGS				COMMENTS	
		OK	FIXED	N/A	FAULTY		
GENERAL							
1	TAGGING		X			<i>Calibration by means of Simulating Channel Level</i> Milltronics OCM-III Configuration	
2						Flume Type = Parshall Size = 12"	
MECHANICAL							
3	MOUNTING: check for proper fastening, etc.	X				P46 - Zero Head = 176.3498 cm	
4	ORIENTATION: check for proper angle, etc.)	X				P7 - Max. Head = 44.1699 cm	
5	POSITION: relative position to other components (ie. for proper flow, blanking distance), etc.	X				P1 Linear Units = cm Flow Units = l/s	
6						Type = Flow Parshall	Damping = 20%
ELECTRICAL							
7		X				Relay 1 = Off Relay 2 = Off Relay 2 = Off	
8	WIRE TAGGING: (exists and proper wire type)	X				Trending Configuration Sample at 60 min. Intervals	
9	QUALITY OF CONNECTIONS:	X					
10	GROUNDING:	X					
11	SHIELDING: (check if grounded only at PLC end of wire)	X					
12	CERTIFICATION CSA, ULC:	X					
SET-UP/CALIBRATION							
DIGITAL			ADJUSTMENT USING		VERIFIED USING		SETPOINT / RANGE
14	SETPOINT ADJUSTMENT	MECHANICAL TYPE			Level Target		
		ELECTRONIC TYPE			Fluke 752 calibrator S/N 8759025		0 – 198.7 l/sec
Configuration Parameters:			Calibration Data Test Tolerance: 5.00%				
			Input Variable	Transmitter Value.	Cal. Value	% Error	Notes
(Calibration Jig set to 0.211 m)			0.213 m	65.46 l/s	64.18 l/s	0.64 %	Passed
(Calibration Jig set to 0.064 m)			0.065 m	12.33 l/s	10.20 l/s	1.07 %	Passed
$\text{Error (\% Full Scale)} = ((\text{Transmitter Value} - \text{Calculated Variable}) / \text{Full Scale}) * 100$ $= ((65.46 - 64.18) / 198.7) * 100$ $= 0.64 \% \text{ of full scale}$							Checked By: <i>Tim Stewart</i> Cell: 613 325 9213 Email: tim.stewart@capitalcontrols.ca

CapitalControls

Electrical/Control Panels – PLC/SCADA Programming – Instrumentation Calibrations

830 Industrial Ave. Ottawa, ON K1G-4B8 Ph. 613 248-1999 Fax: 613 248-1997

5.5 FIT-901 Effluent Pump Flow:

FIELD EQUIPMENT VERIFICATION / CALIBRATION REPORT

DATE: July 29 / 2019

DESCRIPTION: Iroquois WPCP Effluent Pump Flow		MODEL: 7ME69201AA101AA0		TAG: FIT-901	
MANUFACTURER : Siemens		Serial N1D6053478			
Client Name: Township of South Stormont .		Device Output Signal : 4.00 - 20.0 mA			
INSTALLATION INSPECTION					
	DESCRIPTION	FINDINGS			COMMENTS
		OK	FIXED	N/A	
GENERAL					
1	TAGGING		X		- Flow Verification by means of Coil Verification and output measurement
2					
MECHANICAL					Coil resistance : 113.1 Ohms = passed
3	MOUNTING: Check for proper fastening, etc.	X			
4	CELL: Check Operation / Slope, etc.)	X			
5	POSITION: Relative position to other components (ie. for proper flow, blanking distance), etc.	X			
6	Cleaning: Check for Staining or Deposits, etc.)				
ELECTRICAL					
7		X			
8	WIRE TAGGING: (exists and proper wire type)	X			
9	QUALITY OF CONNECTIONS:	X			
10	GROUNDING:	X			
11	SHIELDING: (check if grounded only at PLC end of wire)	X			
12	CERTIFICATION CSA, ULC:	X			
SET-UP/CALIBRATION					
DIGITAL		ADJUSTMENT USING		VERIFIED USING	
14	SETPOINT ADJUSTMENT	MECHANICAL TYPE			
		ELECTRONIC TYPE		Fluke 725 calibrator S/N 8759025	0.0 – 75.0 l/Sec = 4.00 to 20.0 mA
Configuration Parameters:		Calibration Data Test		Tolerance: 5.0%	
		Transmitter Value	SCADA Value	% Error	Status
					Notes
FIT-901		4.8 l/s	4.7 l/s	0.13%	Passed
					Checked By: Tim Stewart
Error (% Full Scale) = ((Transmitter Value - SCADA Value) / Full Scale) * 100 = ((4.8-4.7) / 75) *100 = 0.13 % of full scale					Cell: 613 25 9213 Email: tim.stewart@capitalcontrols.ca

CapitalControls

Electrical/Control Panels – PLC/SCADA Programming – Instrumentation Calibrations

830 Industrial Ave. Ottawa, ON K1G-4B8 Ph. 613 248-1999 Fax: 613 248-1997

5.6 FIT-304 Raw Waste Water Flow:

FIELD EQUIPMENT VERIFICATION / CALIBRATION REPORT

DATE: July 29 2019

DESCRIPTION: Iroquois WPCP Raw Water Flow		MODEL: 7ME65204PJ132AA2		TAG: FIT-304	
MANUFACTURER : Siemens FM MAG 5100W		Serial: 192102H243			
Client Name: Township of South Stormont .		Device Output Signal : 4.00 - 20.0 mA			
INSTALLATION INSPECTION					
	DESCRIPTION	FINDINGS			COMMENTS
		OK	FIXED	N/A	
GENERAL					
1	TAGGING		X		Flow verification by coil verification and output measurement
2					
MECHANICAL					
3	MOUNTING: Check for proper fastening, etc.	X			
4	CELL: Check Operation / Slope, etc.)	X			
5	POSITION: Relative position to other components (ie. for proper flow, blanking distance), etc.	X			
6	Cleaning: Check for Staining or Deposits, etc.)				
ELECTRICAL					
7		X			
8	WIRE TAGGING: (exists and proper wire type)	X			
9	QUALITY OF CONNECTIONS:	X			
10	GROUNDING:	X			
11	SHIELDING: (check if grounded only at PLC end of wire)	X			
12	CERTIFICATION CSA, ULC:	X			
SET-UP/CALIBRATION					
DIGITAL		ADJUSTMENT USING		VERIFIED USING	
14	SETPOINT ADJUSTMENT	MECHANICAL TYPE			
		ELECTRONIC TYPE		Fluke 725 calibrator S/N 8759025	0.0 – 300.0 l/Sec = 4.00 to 20.0 mA
Configuration Parameters:		Calibration Data Test		Tolerance: 5.0%	
		Transmitter Value	SCADA Value	% Error	Status
FIT-304		61.0 l/s	59.8 l/s	0.063%	Passed
Error (% Full Scale) = ((Transmitter Value – SCADA Value) / Full Scale) * 100 = ((61.0-59.8) / 300)*100 = 0.06 % of full scale					Checked By: Tim Stewart Cell: 613 325 9213 Email: tim.stewart@capitalcontrols.ca

CapitalControls

Electrical/Control Panels – PLC/SCADA Programming – Instrumentation Calibrations

830 Industrial Ave. Ottawa, ON K1G-4B8 Ph. 613 248-1999 Fax: 613 248-1997

5.7 FIT-302 P.S Inlet Sewage Flow:

FIELD EQUIPMENT VERIFICATION / CALIBRATION REPORT

DATE: July 29 / 2019

DESCRIPTION: Iroquois WPCP Inlet Sewage Flow Elizabeth St. Pump Station		MODEL: 7ME65204PJ132AA2		TAG: FIT-302	
MANUFACTURER : Siemens FM MAG 6000W		Serial: N1D2087032			
Client Name: Township of South Stormont .		Device Output Signal : 4.00 - 20.0 mA			
INSTALLATION INSPECTION					
	DESCRIPTION	FINDINGS			COMMENTS
		OK	FIXED	N/A	
GENERAL					
1	TAGGING		X		Flow verification by coil verification and output measurement
2					
MECHANICAL					
3	MOUNTING: Check for proper fastening, etc.	X			
4	CELL: Check Operation / Slope, etc.)	X			
5	POSITION: Relative position to other components (ie. for proper flow, blanking distance), etc.	X			
6	Cleaning: Check for Staining or Deposits, etc.)				
ELECTRICAL					
7		X			
8	WIRE TAGGING: (exists and proper wire type)	X			
9	QUALITY OF CONNECTIONS:	X			
10	GROUNDING:	X			
11	SHIELDING: (check if grounded only at PLC end of wire)	X			
12	CERTIFICATION CSA, ULC:	X			
13					
SET-UP/CALIBRATION					
DIGITAL		ADJUSTMENT USING		VERIFIED USING	
14	SETPOINT ADJUSTMENT	MECHANICAL TYPE			
		ELECTRONIC TYPE		Fluke 725 calibrator S/N 8759025	0.0 – 400.0 l/Sec = 4.00 to 20.0 mA
Configuration Parameters:		Calibration Data Test		Tolerance: 5.0%	
		Input Variable	Output Variable	% Error	Status
FIT-302		84.1 l/Sec	85.2	0.28%	Passed
Error (% Full Scale) = ((Transmitter Value – SCADA Value) / Full Scale) * 100 = ((84.1-85.2) / 400) * 100 = -0.28 % of full scale					
Checked By: Tim Stewart Cell: 613 325 9213 Email: tim.stewart@capitalcontrols.ca					

CapitalControls

Electrical/Control Panels – PLC/SCADA Programming – Instrumentation Calibrations

830 Industrial Ave. Ottawa, ON K1G-4B8 Ph. 613 248-1999 Fax: 613 248-1997

5.8 FIT-301 Inlet Sewage Plant Pump Station Flow

FIELD EQUIPMENT VERIFICATION / CALIBRATION REPORT						
DATE: July 29 / 2019						
DESCRIPTION: Iroquois Inlet Sewage Plant P.S Flow Sewage Flow			MODEL: 7ME69201AA101AA0		TAG: FIT-301	
MANUFACTURER : Siemens FM MAG 6000			Serial: N1D2087032			
Client Name: Township of South Stormont .			Device Output Signal : 4.00 - 20.0 mA			
INSTALLATION INSPECTION						
	DESCRIPTION	FINDINGS			COMMENTS	
		OK	FIXED	N/A		
GENERAL						
1	TAGGING		X		- Flow Verification by means of coil verification and output measurement	
2						
MECHANICAL						
3	MOUNTING: Check for proper fastening, etc.	X				
4	CELL: Check Operation / Slope, etc.)	X				
5	POSITION: Relative position to other components (ie. for proper flow, blanking distance), etc.	X				
6	Cleaning: Check for Staining or Deposits, etc.)					
ELECTRICAL						
7		X				
8	WIRE TAGGING: (exists and proper wire type)	X				
9	QUALITY OF CONNECTIONS:	X				
10	GROUNDRING:	X				
11	SHIELDING: (check if grounded only at PLC end of wire)	X				
12	CERTIFICATION CSA, ULC:	X				
SET-UP/CALIBRATION						
DIGITAL		ADJUSTMENT USING		VERIFIED USING		SETPOINT / RANGE
14	SETPOINT ADJUSTMENT	MECHANICAL TYPE				
		ELECTRONIC TYPE			Fluke 725 calibrator S/N 8759025	0.0 – 400.0 l/Sec = 4.00 to 20.0 mA
Configuration Parameters:		Calibration Data Test			Tolerance: 5.0%	
		Transmitter Value	SCADA Value	% Error	Status	Notes
FIT- 301		53.9 l/sec	53.6 l/sec	0.08%	Passed	
Error (% Full Scale) = ((Transmitter Value – SCADA Value) / Full Scale) * 100 = ((53.9-53.6) / 400) *100 = 0.08 % of full scale					Checked By: Tim Stewart Cell: 613 325 9213 Email: tim.stewart@capitalcontrols.ca	

CapitalControls

Electrical/Control Panels ~ PLC/SCADA Programming ~ Instrumentation Calibrations

830 Industrial Ave. Ottawa, ON K1G-4B8 Ph. 613 248-1999 Fax: 613 248-1997

5.9 FIT-501 U.V Inlet Channel Flow:

FIELD EQUIPMENT VERIFICATION / CALIBRATION REPORT

DATE: July 29/ 2019

DESCRIPTION: Iroquois U.V Inlet Channel Flow		MODEL: OCM Pro CF		TAG: FIT-501	
MANUFACTURER : Nivus		Serial: N1D2087032			
Client Name: Township of South Stormont .		Device Output Signal : 4.00 - 20.0 mA			
INSTALLATION INSPECTION					
	DESCRIPTION	FINDINGS			COMMENTS
		OK	FIXED	N/A	
GENERAL					
1	TAGGING		X		Channel Configuration: H = 0.868m
2					B = 0.900m
MECHANICAL					
3	MOUNTING: Check for proper fastening, etc.	X			Sensor Configuration:
4	CELL: Check Operation / Slope, etc.)	X			$h_{Sensor} = 0.000 \text{ m}$ (at bottom) $h_{max} = 0.868$ (max level)
5	POSITION: Relative position to other components (ie. for proper flow, blanking distance), etc.	X			Velocity = Sensor#1 Mounting = 0.000m Wedge Pos. Average = X1
6	Cleaning: Check for Staining or Deposits, etc.)				
ELECTRICAL					
7		X			Analog Configuration: Channel 1 = 0/4 mA to 20 mA
8	WIRE TAGGING: (exists and proper wire type)	X			Communications:
9	QUALITY OF CONNECTIONS:	X			Mask I/P = 255.255.255.0
10	GROUNDING:	X			Remote I/P = 192.168.000.010
11	SHIELDING: (check if grounded only at PLC end of wire)	X			Gateway = 192.168.000.001
12	CERTIFICATION CSA, ULC:	X			Calculated l/sec. = $(0.868 \times 0.900 \times (0.848/0.289))1000$
SET-UP/CALIBRATION					
DIGITAL		ADJUSTMENT USING		VERIFIED USING	
14	SETPOINT ADJUSTMENT	MECHANICAL TYPE			
		ELECTRONIC TYPE	Fluke 725 calibrator S/N 8759025		0 - 400.0 l/Sec = 4.00 to 20.0 mA
Configuration Parameters: FIT-501		Calibration Data Test		Tolerance: 5% Status Notes	
Velocity	Area	Transmitter Variable	Calculated Variable	% Error	
0.244 m/sec	.875 x .900 = .788 m ²	190.2 l/sec	192.1 l/sec	0.45%	passed
0.217 m/sec	.874 x .900 = .735 m ²	169.5 l/sec	170.6 l/sec	0.28%	passed
NOTES:*** Error (% Full Scale) = ((Calculated Variable – Transmitter Variable) / Full Scale) * 100 = (192 - 190.2)/400 *100 = -.45 % of full scale		Checked By: Tim Stewart Cell: 613 325 9213 Email: tim.stewart@capitalcontrols.ca			