



**Ontario Clean Water Agency**  
**Agence Ontarienne Des Eaux**

Ontario Clean Water Agency  
5 Industrial Dr.  
Chesterville, ON K0C 1H0  
Phone: 613-448-3098  
Fax: 613-448-1616

March 27, 2018

Ministry of the Environment and Climate Change  
Kingston District Office  
1259 Gardiners Rd.  
Kingston, ON K7M 8S5

**Attention:** Mr. James Mahoney, Supervisor

Dear Mr. Mahoney,

**SUBJECT: Iroquois Wastewater Treatment Plant - 2017 Annual Report**

Please find attached the 2017 Annual Performance Report for the Iroquois Wastewater Treatment Plant. This report was completed in accordance with Section 10(6) of Amended Certificate of Approval No. 9689-8MQHNC. The report was prepared by the Ontario Clean Water Agency on behalf of the Municipality of South Dundas, based on the information provided. The report covers the period from January 1, 2017 to December 31, 2017.

Should you require any further information in relation to this report, please do not hesitate to contact our office.

Yours truly,

A handwritten signature in blue ink, appearing to read "Dawn Crump".

Dawn Crump  
Process and Compliance Technician  
Seaway Valley Cluster

c.c. Shannon Geraghty, C.A.O./Treasurer, Municipality of South Dundas  
Denis Villeneuve, Supervisor of Water/Wastewater Operations, Municipality of South Dundas  
Brenda Beaudoin, Provincial Officer, MOECC

## **Iroquois Wastewater Treatment Plant** **2017 Annual Performance Report**

The Iroquois WWTP is a Class II wastewater treatment facility owned and operated by the Municipality of South Dundas. Raw sewage is conveyed from the collection system to the plant pumping station which is equipped with three submersible pumps. From the pumping station, wastewater passes through the inlet works, including mechanically cleaned fine screens and a grit removal and disposal system. Aluminum Sulphate is added to assist in phosphorous removal. The wastewater then moves through either of two parallel Sequential Batch Reactors (SBR) equipped with individual aeration systems, mixers, decanters and sludge removal pumps. Effluent decanted from the SBRs is treated by UV disinfection and subsequently passes through an outfall pipe to the St. Lawrence River.

Sludge removed from the SBRs is transferred to a waste activated sludge tank. From the tank, the sludge enters a rotary drum thickener. Polymer is added to assist with the thickening process. Thickened sludge is pumped to an Autothermal Thermophilic Aerobic Digestion (ATAD) system for stabilization. The ATAD system is equipped with an off-gas scrubber and biofilter to provide odour control. The digested sludge is then pumped to one of three biosolids storage tanks. From the storage tanks, biosolids are hauled off site to be utilized as soil conditioner.

The following report addresses the requirements outlined in Condition 10 (6) of Amended Certificate of Approval #9689-8MQHNK issued on October 25, 2011.

***10(6) The Owner shall prepare and submit to the District Manager, a performance report, on an annual basis, within ninety (90) days following the end of the period being reported upon. The first such report shall cover the first annual period following the commencement of operation of the Works and subsequent reports shall be submitted to cover successive annual periods following thereafter. The reports shall contain, but shall not be limited to, the following information:***

***(a) a summary and interpretation of all monitoring data and a comparison to the effluent limits outlined in Condition 7, including an overview of the success and adequacy of the Works;***

The total volume of effluent discharged in 2017 was approximately 1,073,508 m<sup>3</sup>. The average rate of discharge was 2,938 m<sup>3</sup>/day which represents 89% of the 3,300 m<sup>3</sup>/day design flow. The calculated percent removal of CBOD<sub>5</sub>, TSS, TP and TAN in the final effluent described in the following paragraphs was determined using data from weekly effluent samples and monthly raw sewage composite sample results for the reporting period.

The allowable monthly average concentration for CBOD<sub>5</sub> in the effluent as stated in Condition 7 is 25 mg/L. The corresponding loading limit is 82.5 kg/day. Average concentrations and loadings were well below the limits specified in the ECA. For 2017, the average CBOD<sub>5</sub> in the effluent was 3.2 mg/L which represents approximately 81% removal of CBOD<sub>5</sub> from the raw sewage. The average loading rate for 2017 was 9.4 kg/day which is 11% of the allowable limit of 82.5 kg/day.

The allowable monthly average concentration for Total Suspended Solids (TSS) as stated in Condition 7 is 25mg/L. The corresponding loading limit is 82.5 kg/day. Average concentrations and loadings remained well below the limits specified in the ECA. In 2017, the average concentration of TSS in the effluent was approximately 4.35 mg/L which represents approximately 79% removal of TSS from the raw influent. The average loading rate for 2017 was 12.8 kg/day which is 15.5% of the allowable 82.5 kg/day limit.

The monthly average concentration limit for Total Phosphorus (TP) as stated in Condition 7 is 1.0 mg/L. The corresponding loading limit is 3.3 kg/day. Average concentrations and loadings remained below the limits specified in the ECA. The average monthly concentration during the reporting period was 0.22 mg/L which represents 76% removal of TP from the raw influent. The average monthly loading for 2017 was 0.65 kg/day which is 20% of the allowable 3.3 kg/day limit.

The monthly average concentration limit for total ammonia nitrogen (TAN) as stated in Condition 7 is 10 mg/L from June through September and 15 mg/L from October through May. The monthly average loading limit is 33.0 kg/day and 49.5, respectively. The average monthly concentration during the June - September reporting period was 0.13 mg/L. The average monthly loading during that time was 0.38 kg/day which is 1.2% of the allowable 33.0 kg/day limit. The average monthly concentration during the October - May reporting period was 0.02 mg/L. The average monthly loading during that time was 0.07 kg/day which is 0.14% of the allowable 49.5 kg/day limit.

Condition 7 stipulates that the *E. coli* monthly geometric mean density must not exceed 200 organisms/100 mL of effluent. During 2017, the average monthly geometric mean was 3.75 CFU/100 mL which did not exceed the monthly limit.

Condition 7 also requires the effluent to be non-acutely lethal to Rainbow Trout and *Daphnia Magna*, with grab samples being collected on an annual basis. The effluent sample collected on April 4, 2017 caused 0% mortality.

The pH of the effluent remained within the range of 6.0 - 9.5 specified in Table 2.

A summary of flow rates, monitoring data and laboratory results can be found in Appendix A.

***(b) a description of any operating problems encountered and corrective actions taken;***

Please see the Call-Out Summary in Appendix B.

***(c) a summary of all maintenance carried out on any major structure, equipment, apparatus, mechanism or thing part of the Works;***

Please see the Major Maintenance Project Summary in Appendix C.

***(d) a summary of any effluent quality assurance or control measures undertaken in the reporting period;***

Effluent samples are collected by the Municipality of South Dundas' licensed operational staff on a weekly basis. All samples are analyzed by a laboratory accredited by the Canadian Association for Laboratory Accreditation (CALA). Accreditation ensures that the laboratory has acceptable laboratory protocols and test methods in place. It also requires the laboratory to provide evidence and assurances of the proficiency of the analysts performing the test methods.

***(e) a summary of the calibration and maintenance carried out on all effluent monitoring equipment***

The annual calibration and verification reports can be found attached in Appendix D.

***(f) a description of efforts made and results achieved in meeting the Effluent Objectives of Condition 6;***

Condition 6.1 - During the reporting period all monthly average concentrations of CBOD<sub>5</sub>, TSS, TP and TAN were below the effluent objectives. The *E. coli* monthly geometric means were also below the stated objective.

Condition 6.2 (a) - Effluent pH remained within the 6.5- 9.5 range specified in the ECA.

Condition 6.2 (b) - The monthly average day flows remained below the 3,300 m<sup>3</sup>/day design capacity. In addition, the daily maximum rated capacity of 16,800 m<sup>3</sup>/day was not exceeded in 2017.

Condition 6.2 (c) - Effluent was essentially free of floating or settleable solids and did not contain substances that would cause a film, sheen, foam or discoloration to the receiving stream.

***(g) a tabulation of the volume of sludge generated in the reporting period, an outline of anticipated volumes to be generated in the next reporting period and a summary of the locations to where the sludge was disposed;***

In 2017, a total of 808.5 m<sup>3</sup> of liquid biosolids was utilized as soil conditioner. Of this, 446 m<sup>3</sup> was land applied in June, and 304 m<sup>3</sup> was land applied in November (NASM Plan #21084). Another 58.5 m<sup>3</sup> was hauled to D.E.S. Environmental Services Inc. in April. It is anticipated that approximately the same volume of sludge will be generated in 2018.

***(h) a summary of any complaints received during the reporting period and any steps taken to address the complaints;***

There were no complaints received in relation to the Iroquois WWTP during the reporting period.

***(i) a summary of all By-pass, spill or abnormal discharge events;***

Two bypass events occurred in 2017:

| Date     | Start Time | End Time | Duration (hh:mm) | Estimated Volume (m3) | SAC Ref. # |
|----------|------------|----------|------------------|-----------------------|------------|
| 04-07-17 | 03:43      | 04:23    | 00:40            | 56.3                  | 900666     |
|          | 05:36      | 05:58    | 00:22            | 18.3                  |            |
| 10-30-17 | 09:54      | 15:10    | 01:52            | 149                   | 901656     |

In both cases, heavy precipitation resulted in partially treated wastewater being discharged from the WWTP. Samples were collected and the bypasses were reported in accordance with federal and provincial requirements.

***(j) any other information the District Manager requires from time to time.***

No requests for additional information have been received.

**APPENDIX A:**  
OPERATIONAL DATA

# IROQUOIS WWTP PERFORMANCE ASSESSMENT REPORT

MUNICIPALITY: SOUTH DUNDAS  
PROJECT: IROQUOIS WWTP

WORKS NUM.: 120000159

DESCRIPTION: TWO SEQUENTIAL BATCH REACTORS AND AEROBIC SLUDGE DIGESTION

YEAR: 2017  
WATER COURSE: ST. LAWRENCE  
DESIGN CAPACITY: 3,300 m<sup>3</sup>/d

| MONTH      | RAW                          |                                |                                   | TREATED                      |                                |                                   | RAW               |                   |                     |                   | SLUDGE                                 |
|------------|------------------------------|--------------------------------|-----------------------------------|------------------------------|--------------------------------|-----------------------------------|-------------------|-------------------|---------------------|-------------------|--|
|            | Total Flow<br>m <sup>3</sup> | Avg Day Flow<br>m <sup>3</sup> | Max Day Flow<br>m <sup>3</sup> /d | Total Flow<br>m <sup>3</sup> | Avg Day Flow<br>m <sup>3</sup> | Max Day Flow<br>m <sup>3</sup> /d | Raw BOD<br>(mg/L) | Raw TSS<br>(mg/L) | Raw PHOS.<br>(mg/L) | Raw TKN<br>(mg/L) | Liquid Sludge Hauled<br>m <sup>3</sup> |
| JAN        | 90,568                       | 2,922                          | 5,365                             | 89,039                       | 2,872                          | 5,184                             | 23                | 14                | 0.70                | 7.0               | 0                                      |
| FEB        | 72,736                       | 2,598                          | 5,848                             | 67,960                       | 2,427                          | 5,833                             | 46                | 26                | 1.08                | 9.5               | 0                                      |
| MAR        | 88,117                       | 2,842                          | 5,371                             | 87,207                       | 2,813                          | 5,550                             | 15                | 18                | 0.91                | 8.5               | 0                                      |
| APR        | 138,637                      | 4,621                          | 14,777                            | 137,746                      | 4,592                          | 15,581                            | 12                | 19                | 0.62                | 5.1               | 58.5                                   |
| MAY        | 117,209                      | 3,781                          | 9,229                             | 116,860                      | 3,770                          | 8,973                             | 37                | 26                | 0.79                | 7.5               | 0                                      |
| JUN        | 73,742                       | 2,458                          | 7,451                             | 72,894                       | 2,430                          | 7,828                             | 9                 | 11                | 1.02                | 9.9               | 446                                    |
| JUL        | 139,157                      | 4,489                          | 15,775                            | 139,498                      | 4,500                          | 15,720                            | 3                 | 7                 | 1.97                | 15.4              | 0                                      |
| AUG        | 83,040                       | 2,679                          | 6,018                             | 85,189                       | 2,748                          | 6,381                             | 14                | 36                | 1.00                | 9.9               | 0                                      |
| SEPT       | 49,391                       | 1,646                          | 3,186                             | 48,282                       | 1,609                          | 3,013                             | 11                | 36                | 0.61                | 6.3               | 0                                      |
| OCT        | 65,203                       | 2,103                          | 15,879                            | 62,603                       | 2,019                          | 14,927                            | 5                 | 8                 | 0.52                | 6.2               | 0                                      |
| NOV        | 107,872                      | 3,596                          | 7,636                             | 105,389                      | 3,513                          | 7,359                             | 28                | 27                | 0.78                | 7.8               | 304                                    |
| DEC        | 61,606                       | 1,987                          | 2,816                             | 60,841                       | 1,963                          | 2,836                             | 3                 | 29                | 0.92                | 8.5               | 0                                      |
| TOTAL      | 1,087,278                    |                                |                                   | 1,073,508                    |                                |                                   |                   |                   |                     |                   | 808.5                                  |
| AVG        |                              | 2,977                          |                                   |                              | 2,938                          |                                   | 17                | 21                | 0.91                | 8.5               |  |
| MAX        |                              |                                | 15,879                            |                              |                                | 15,720                            |                   |                   |                     |                   |  |
| CRITERIA   |                              | 3,300                          | 16,800                            |                              |                                |                                   |                   |                   |                     |                   |  |
| COMPLIANCE |                              | YES                            | YES                               |                              |                                |                                   |                   |                   |                     |                   |  |

## 2017 - IROQUOIS WWTP EFFLUENT SAMPLING MONTHLY AVERAGES

| MONTH     | DATE            |   | CBOD (mg/L) |   | TSS (mg/L) |  | TP (mg/L) |   | NH <sub>3</sub> (mg/L) |   | E. Coli (CFU/100ml) |
|-----------|-----------------|---|-------------|---|------------|--|-----------|---|------------------------|---|---------------------|
| January   | 01/05/2017      | < | 3           |   | 3          |  | 0.18      | < | 0.01                   | < | 2                   |
|           | 01/12/2017      | < | 3           | < | 3          |  | 0.21      | < | 0.01                   |   | 4                   |
|           | 01/19/2017      | < | 3           | < | 3          |  | 0.15      | < | 0.01                   |   | 2                   |
|           | 01/26/2017      | < | 3           | < | 3          |  | 0.17      | < | 0.01                   | < | 2                   |
|           |                 |   |             |   |            |  |           |   |                        |   |                     |
|           | Monthly Average |   | 3.0         |   | 3.0        |  | 0.18      |   | 0.01                   |   | 2                   |
| February  | Compliant?      |   | YES         |   | YES        |  | YES       |   | YES                    |   | YES                 |
|           | 02/02/2017      | < | 3           | < | 3          |  | 0.2       | < | 0.01                   |   | 2                   |
|           | 02/09/2017      | < | 3           |   | 3          |  | 0.17      | < | 0.01                   |   | 18                  |
|           | 02/16/2017      | < | 3           | < | 3          |  | 0.2       |   | 0.01                   |   | 8                   |
|           | 02/23/2017      | < | 3           |   | 8          |  | 0.24      | < | 0.01                   |   | 6                   |
|           |                 |   |             |   |            |  |           |   |                        |   |                     |
| March     | Monthly Average |   | 3.0         |   | 4.3        |  | 0.20      |   | 0.01                   |   | 6                   |
|           | Compliant?      |   | YES         |   | YES        |  | YES       |   | YES                    |   | YES                 |
|           | 03/02/2017      | < | 3           |   | 6          |  | 0.2       |   | 0.08                   |   | 10                  |
|           | 03/09/2017      | < | 3           |   | 6          |  | 0.27      |   | 0.01                   |   | 2                   |
|           | 03/16/2017      | < | 3           |   | 8          |  | 0.22      |   | 0.02                   | < | 2                   |
|           | 03/23/2017      | < | 3           |   | 4          |  | 0.25      |   | 0.02                   |   | 4                   |
| April     | 03/30/2017      | < | 3           |   | 6          |  | 0.24      | < | 0.01                   |   | 4                   |
|           | Monthly Average |   | 3.0         |   | 6.0        |  | 0.24      |   | 0.03                   |   | 4                   |
|           | Compliant?      |   | YES         |   | YES        |  | YES       |   | YES                    |   | YES                 |
|           | 04/06/2017      | < | 3           | < | 3          |  | 0.23      |   | 0.06                   |   | 2                   |
|           | 04/11/2017      |   | 7           |   | 4          |  | 0.25      |   | 0.03                   |   | 2                   |
|           | 04/20/2017      | < | 3           |   | 3          |  | 0.16      |   | 0.06                   | < | 2                   |
| May       | 04/27/2017      | < | 3           |   | 4          |  | 0.21      |   | 0.03                   | < | 2                   |
|           |                 |   |             |   |            |  |           |   |                        |   |                     |
|           | Monthly Average |   | 4.0         |   | 3.5        |  | 0.21      |   | 0.05                   |   | 2                   |
|           | Compliant?      |   | YES         |   | YES        |  | YES       |   | YES                    |   | YES                 |
|           | 05/04/2017      | < | 3           |   | 6          |  | 0.29      |   | 0.06                   |   | 2                   |
|           | 05/11/2017      | < | 3           |   | 9          |  | 0.31      |   | 0.03                   | < | 2                   |
| June      | 05/18/2017      | < | 3           |   | 7          |  | 0.28      |   | 0.04                   |   | 4                   |
|           | 05/25/2017      | < | 3           |   | 3          |  | 0.21      |   | 0.05                   |   | 8                   |
|           |                 |   |             |   |            |  |           |   |                        |   |                     |
|           | Monthly Average |   | 3.0         |   | 6.3        |  | 0.27      |   | 0.05                   |   | 3                   |
|           | Compliant?      |   | YES         |   | YES        |  | YES       |   | YES                    |   | YES                 |
|           | 06/01/2017      | < | 3           |   | 5          |  | 0.24      |   | 0.03                   |   | 6                   |
| July      | 06/08/2017      | < | 3           |   | 3          |  | 0.27      |   | 0.05                   |   | 6                   |
|           | 06/15/2017      | < | 3           |   | 3          |  | 0.24      |   | 0.02                   | < | 2                   |
|           | 06/22/2017      | < | 3           |   | 5          |  | 0.24      | < | 0.01                   |   | 12                  |
|           | 06/29/2017      | < | 3           | < | 3          |  | 0.23      | < | 0.01                   |   | 4                   |
|           | Monthly Average |   | 3.0         |   | 3.8        |  | 0.24      |   | 0.02                   |   | 5                   |
|           | Compliant?      |   | YES         |   | YES        |  | YES       |   | YES                    |   | YES                 |
| August    | 07/06/2017      | < | 3           |   | 5          |  | 0.25      |   | 0.05                   |   | 72                  |
|           | 07/13/2017      | < | 3           | < | 3          |  | 0.23      | < | 0.01                   |   | 2                   |
|           | 07/20/2017      | < | 3           | < | 3          |  | 0.2       | < | 0.01                   |   | 2                   |
|           | 07/27/2017      | < | 3           |   | 5          |  | 0.29      |   | 1.7                    |   | 2                   |
|           |                 |   |             |   |            |  |           |   |                        |   |                     |
|           | Monthly Average |   | 3.0         |   | 4.0        |  | 0.24      |   | 0.44                   |   | 5                   |
| September | Compliant?      |   | YES         |   | YES        |  | YES       |   | YES                    |   | YES                 |
|           | 08/03/2017      | < | 3           |   | 3          |  | 0.13      | < | 0.01                   |   | 6                   |
|           | 08/10/2017      | < | 3           |   | 3          |  | 0.15      |   | 0.05                   |   | 8                   |
|           | 08/17/2017      | < | 3           | < | 3          |  | 0.14      | < | 0.01                   |   | 2                   |
|           | 08/24/2017      | < | 3           | < | 3          |  | 0.15      | < | 0.01                   |   | 6                   |
|           | 08/31/2017      | < | 3           | < | 3          |  | 0.19      |   | 0.02                   | < | 2                   |
| October   | Monthly Average |   | 3.0         |   | 3.0        |  | 0.15      |   | 0.02                   |   | 4                   |
|           | Compliant?      |   | YES         |   | YES        |  | YES       |   | YES                    |   | YES                 |
|           | 09/07/2017      | < | 3           | < | 3          |  | 0.14      |   | 0.02                   |   | 4                   |
|           | 09/14/2017      | < | 3           |   | 6          |  | 0.17      |   | 0.05                   |   | 2                   |
|           | 09/21/2017      | < | 3           |   | 5          |  | 0.17      | < | 0.01                   |   | 104                 |
|           | 09/28/2017      | < | 3           |   | 3          |  | 0.14      |   | 0.1                    |   | 8                   |
| November  |                 |   |             |   |            |  |           |   |                        |   |                     |
|           | Monthly Average |   | 3.0         |   | 4.25       |  | 0.16      |   | 0.05                   |   | 9                   |
|           | Compliant?      |   | YES         |   | YES        |  | YES       |   | YES                    |   | YES                 |
|           | 10/05/2017      | < | 3           | < | 3          |  | 0.14      |   | 0.01                   | < | 2                   |
|           | 10/12/2017      | < | 4           | < | 3          |  | 0.13      |   | 0.01                   | < | 2                   |
|           | 10/19/2017      | < | 5           | < | 3          |  | 0.13      | < | 0.01                   |   | 4                   |
| December  | 10/26/2017      | < | 6           | < | 3          |  | 0.18      | < | 0.01                   |   | 4                   |
|           |                 |   |             |   |            |  |           |   |                        |   |                     |
|           | Monthly Average |   | 4.5         |   | 3.0        |  | 0.15      |   | 0.01                   |   | 3                   |
|           | Compliant?      |   | YES         |   | YES        |  | YES       |   | YES                    |   | YES                 |
|           | 11/02/2017      | < | 3           |   | 7          |  | 0.27      | < | 0.01                   |   | 4                   |
|           | 11/09/2017      | < | 3           |   | 8          |  | 0.36      | < | 0.01                   |   | 4                   |
| January   | 11/16/2017      | < | 3           | < | 3          |  | 0.32      | < | 0.01                   |   | 2                   |
|           | 11/23/2017      | < | 3           |   | 8          |  | 0.39      | < | 0.01                   |   | 2                   |
|           | 11/30/2017      | < | 3           | < | 3          |  | 0.3       | < | 0.01                   | < | 2                   |
|           | Monthly Average |   | 3.0         |   | 7.7        |  | 0.33      |   | 0.01                   |   | 2                   |
|           | Compliant?      |   | YES         |   | YES        |  | YES       |   | YES                    |   | YES                 |
|           | 12/07/2017      | < | 3           |   | 5          |  | 0.37      | < | 0.01                   |   | 2                   |
| February  | 12/14/2017      | < | 3           |   | 3          |  | 0.27      | < | 0.01                   | < | 2                   |
|           | 12/21/2017      | < | 3           | < | 3          |  | 0.37      |   | 0.06                   |   | 10                  |
|           | 12/27/2017      | < | 3           |   | 3          |  | 0.16      |   | 0.05                   | < | 2                   |
|           |                 |   |             |   |            |  |           |   |                        |   |                     |
|           | Monthly Average |   | 3.0         |   | 3.5        |  | 0.29      |   | 0.03                   |   | 3                   |
|           | Compliant?      |   | YES         |   | YES        |  | YES       |   | YES                    |   | YES                 |

## 2017 - IROQUOIS WWTP LOADING CALCULATIONS

| MONTH     | Total Effluent Flow (m <sup>3</sup> ) |                        | BOD   | TSS   | TP   | NH <sub>3</sub> |
|-----------|---------------------------------------|------------------------|-------|-------|------|-----------------|
| January   | 89,039                                | Monthly Average (mg/L) | 3.0   | 3.0   | 0.2  | 0.01            |
|           |                                       | Loading (kg/d)         | 8.62  | 8.62  | 0.51 | 0.03            |
|           |                                       | Compliant?             | YES   | YES   | YES  | YES             |
| February  | 67,960                                | Monthly Average (mg/L) | 3.0   | 4.25  | 0.20 | 0.01            |
|           |                                       | Loading (kg/d)         | 6.58  | 9.32  | 0.44 | 0.02            |
|           |                                       | Compliant?             | YES   | YES   | YES  | YES             |
| March     | 87,207                                | Monthly Average (mg/L) | 3.0   | 6.0   | 0.24 | 0.03            |
|           |                                       | Loading (kg/d)         | 8.44  | 16.88 | 0.66 | 0.08            |
|           |                                       | Compliant?             | YES   | YES   | YES  | YES             |
| April     | 137,746                               | Monthly Average (mg/L) | 4.0   | 3.5   | 0.21 | 0.05            |
|           |                                       | Loading (kg/d)         | 17.77 | 15.55 | 0.94 | 0.20            |
|           |                                       | Compliant?             | YES   | YES   | YES  | YES             |
| May       | 116,860                               | Monthly Average (mg/L) | 3.0   | 6.25  | 0.27 | 0.045           |
|           |                                       | Loading (kg/d)         | 11.31 | 23.56 | 1.03 | 0.17            |
|           |                                       | Compliant?             | YES   | YES   | YES  | YES             |
| June      | 72,894                                | Monthly Average (mg/L) | 3.0   | 3.8   | 0.24 | 0.02            |
|           |                                       | Loading (kg/d)         | 7.05  | 8.94  | 0.57 | 0.06            |
|           |                                       | Compliant?             | YES   | YES   | YES  | YES             |
| July      | 139,498                               | Monthly Average (mg/L) | 3.0   | 4.0   | 0.24 | 0.44            |
|           |                                       | Loading (kg/d)         | 13.50 | 18.00 | 1.09 | 1.99            |
|           |                                       | Compliant?             | YES   | YES   | YES  | YES             |
| August    | 85,189                                | Monthly Average (mg/L) | 3.0   | 3.0   | 0.15 | 0.02            |
|           |                                       | Loading (kg/d)         | 8.24  | 8.24  | 0.42 | 0.05            |
|           |                                       | Compliant?             | YES   | YES   | YES  | YES             |
| September | 48,282                                | Monthly Average (mg/L) | 3.0   | 4.25  | 0.16 | 0.05            |
|           |                                       | Loading (kg/d)         | 4.67  | 6.62  | 0.24 | 0.07            |
|           |                                       | Compliant?             | YES   | YES   | YES  | YES             |
| October   | 62,603                                | Monthly Average (mg/L) | 4.5   | 3.0   | 0.15 | 0.01            |
|           |                                       | Loading (kg/d)         | 9.09  | 6.06  | 0.29 | 0.02            |
|           |                                       | Compliant?             | YES   | YES   | YES  | YES             |
| November  | 105,389                               | Monthly Average (mg/L) | 3.0   | 7.7   | 0.33 | 0.01            |
|           |                                       | Loading (kg/d)         | 10.20 | 26.06 | 1.12 | 0.03            |
|           |                                       | Compliant?             | YES   | YES   | YES  | YES             |
| December  | 60,841                                | Monthly Average (mg/L) | 3.0   | 3.5   | 0.29 | 0.03            |
|           |                                       | Loading (kg/d)         | 5.89  | 6.87  | 0.57 | 0.06            |
|           |                                       | Compliant?             | YES   | YES   | YES  | YES             |



## 2017 - IROQUOIS WWTP EFFLUENT UN-IONIZED AMMONIA

| Sample Date | Sample Temperature ° C | Sample Temp. Kelvin | Dissociation Constant pK <sub>a</sub> | Effluent Sample pH on-site | Fraction of Un-ionized Ammonia | Total Ammonia (mg/L) (NH <sub>3</sub> + NH <sub>4</sub> as N) | Un-ionized Ammonia (mg/L) |
|-------------|------------------------|---------------------|---------------------------------------|----------------------------|--------------------------------|---|---------------------------|
| 01/05/2017  | 10.5                   | 283.65              | 9.71                                  | 8.5                        | 0.0575                         | < 0.01  | 0.0006                    |
| 01/12/2017  | 11.0                   | 284.15              | 9.70                                  | 8.4                        | 0.0480                         | < 0.01  | 0.0005                    |
| 01/19/2017  | 11.5                   | 284.65              | 9.68                                  | 8.4                        | 0.0498                         | < 0.01  | 0.0005                    |
| 01/26/2017  | 10.4                   | 283.55              | 9.72                                  | 8.5                        | 0.0571                         | < 0.01  | 0.0006                    |
| 02/02/2017  | 9.8                    | 282.95              | 9.74                                  | 8.4                        | 0.0439                         | < 0.01  | 0.0004                    |
| 02/09/2017  | 9.1                    | 282.25              | 9.76                                  | 8.4                        | 0.0416                         | < 0.01  | 0.0004                    |
| 02/16/2017  | 9.6                    | 282.75              | 9.75                                  | 8.4                        | 0.0432                         | < 0.01  | 0.0004                    |
| 02/23/2017  | 9.2                    | 282.35              | 9.76                                  | 8.5                        | 0.0522                         | < 0.01  | 0.0005                    |
| 03/02/2017  | 8.4                    | 281.55              | 9.79                                  | 8.4                        | 0.0395                         | < 0.08  | 0.0032                    |
| 03/09/2017  | 9.4                    | 282.55              | 9.75                                  | 8.3                        | 0.0341                         | < 0.01  | 0.0003                    |
| 03/16/2017  | 8.3                    | 281.45              | 9.79                                  | 8.3                        | 0.0314                         | < 0.02  | 0.0006                    |
| 03/23/2017  | 8.8                    | 281.95              | 9.77                                  | 7.9                        | 0.0132                         | < 0.02  | 0.0003                    |
| 03/30/2017  | 8.7                    | 281.85              | 9.78                                  | 8.3                        | 0.0323                         | < 0.01  | 0.0003                    |
| 04/06/2017  | 8.1                    | 281.25              | 9.80                                  | 8.1                        | 0.0197                         | < 0.06  | 0.0012                    |
| 04/11/2017  | 10.9                   | 284.05              | 9.70                                  | 8.0                        | 0.0195                         | < 0.03  | 0.0006                    |
| 04/20/2017  | 9.8                    | 282.95              | 9.74                                  | 7.9                        | 0.0143                         | < 0.06  | 0.0009                    |
| 04/27/2017  | 10.1                   | 283.25              | 9.73                                  | 8.1                        | 0.0230                         | < 0.03  | 0.0007                    |
| 05/04/2017  | 11.4                   | 284.55              | 9.68                                  | 8.0                        | 0.0203                         | < 0.06  | 0.0012                    |
| 05/11/2017  | 10.4                   | 283.55              | 9.72                                  | 8.0                        | 0.0188                         | < 0.03  | 0.0006                    |
| 05/18/2017  | 11.7                   | 284.85              | 9.67                                  | 8.1                        | 0.0260                         | < 0.04  | 0.0010                    |
| 05/25/2017  | 11.3                   | 284.45              | 9.69                                  | 8.0                        | 0.0201                         | < 0.05  | 0.0010                    |
| 06/01/2017  | 12.7                   | 285.85              | 9.64                                  | 7.9                        | 0.0179                         | < 0.03  | 0.0005                    |
| 06/08/2017  | 12.5                   | 285.65              | 9.65                                  | 7.9                        | 0.0176                         | < 0.05  | 0.0009                    |
| 06/15/2017  | 13.5                   | 286.65              | 9.61                                  | 8.1                        | 0.0297                         | < 0.02  | 0.0006                    |
| 06/22/2017  | 13.8                   | 286.95              | 9.60                                  | 7.7                        | 0.0123                         | < 0.01  | 0.0001                    |
| 06/29/2017  | 13.9                   | 287.05              | 9.60                                  | 7.8                        | 0.0156                         | < 0.01  | 0.0002                    |
| 07/06/2017  | 15                     | 288.15              | 9.56                                  | 7.9                        | 0.0212                         | < 0.05  | 0.0011                    |
| 07/13/2017  | 14.4                   | 287.55              | 9.58                                  | 7.7                        | 0.0129                         | < 0.01  | 0.0001                    |
| 07/20/2017  | 15.1                   | 288.25              | 9.56                                  | 7.6                        | 0.0108                         | < 0.01  | 0.0001                    |
| 07/27/2017  | 16.3                   | 289.45              | 9.52                                  | 7.5                        | 0.0094                         | < 1.7   | 0.0160                    |
| 08/03/2017  | 15.4                   | 288.55              | 9.55                                  | 7.9                        | 0.0218                         | < 0.01  | 0.0002                    |
| 08/10/2017  | 16                     | 289.15              | 9.53                                  | 8.2                        | 0.0445                         | < 0.05  | 0.0022                    |
| 08/17/2017  | 16.1                   | 289.25              | 9.53                                  | 8.0                        | 0.0288                         | < 0.01  | 0.0003                    |
| 08/24/2017  | 16.1                   | 289.25              | 9.53                                  | 8.1                        | 0.0360                         | < 0.01  | 0.0004                    |
| 08/31/2017  | 16.2                   | 289.35              | 9.52                                  | 8.0                        | 0.0290                         | < 0.02  | 0.0006                    |
| 09/07/2017  | 16.3                   | 289.45              | 9.52                                  | 7.8                        | 0.0186                         | < 0.02  | 0.0004                    |
| 09/14/2017  | 16.6                   | 289.75              | 9.51                                  | 7.9                        | 0.0239                         | < 0.05  | 0.0012                    |
| 09/21/2017  | 16.8                   | 289.95              | 9.51                                  | 7.7                        | 0.0154                         | < 0.01  | 0.0002                    |
| 09/28/2017  | 16.8                   | 289.95              | 9.51                                  | 7.8                        | 0.0193                         | < 0.1   | 0.0019                    |
| 10/05/2017  | 16.8                   | 289.95              | 9.51                                  | 7.9                        | 0.0242                         | < 0.01  | 0.0002                    |
| 10/12/2017  | 16.1                   | 289.25              | 9.53                                  | 7.9                        | 0.0230                         | < 0.01  | 0.0002                    |
| 10/19/2017  | 15.7                   | 288.85              | 9.54                                  | 7.9                        | 0.0223                         | < 0.01  | 0.0002                    |
| 10/26/2017  | 16.8                   | 289.95              | 9.51                                  | 7.7                        | 0.0154                         | < 0.01  | 0.0002                    |
| 10/30/2017  | 13.5                   | 286.65              | 9.61                                  | 8.2                        | 0.0371                         | < 0.49  | 0.0182                    |
| 11/02/2017  | 15.1                   | 288.25              | 9.56                                  | 7.9                        | 0.0214                         | < 0.01  | 0.0002                    |
| 11/09/2017  | 12.8                   | 285.95              | 9.64                                  | 8.0                        | 0.0225                         | < 0.01  | 0.0002                    |
| 11/16/2017  | 14.6                   | 287.75              | 9.58                                  | 8.3                        | 0.0502                         | < 0.01  | 0.0005                    |
| 11/23/2017  | 12.6                   | 285.75              | 9.64                                  | 8.2                        | 0.0347                         | < 0.01  | 0.0003                    |
| 11/30/2017  | 12.3                   | 285.45              | 9.65                                  | 8.2                        | 0.0340                         | < 0.01  | 0.0003                    |
| 12/07/2017  | 12.2                   | 285.35              | 9.66                                  | 8.2                        | 0.0337                         | < 0.01  | 0.0003                    |
| 12/14/2017  | 12.2                   | 285.35              | 9.66                                  | 8.3                        | 0.0421                         | < 0.01  | 0.0004                    |
| 12/21/2017  | 10.8                   | 283.95              | 9.70                                  | 8.3                        | 0.0379                         | < 0.06  | 0.0023                    |
| 12/27/2017  | 9.9                    | 283.05              | 9.73                                  | 8.3                        | 0.0354                         | < 0.05  | 0.0018                    |

$f = 1/(10^{(pK_a - pH)} + 1)$ , where  $f$  is the decimal fraction of un-ionized ammonia (NH<sub>3</sub>).

$pK_a = 0.09018 + 2729.92/T$ , where  $pK_a$  is the dissociation constant of ammonia at a given temperature.

$T = (K = \text{degrees C} + 273.16)$ , where  $T$  is the ambient water temperature in Kelvin.

## **2017 - IROQUOIS WWTP AEROBIC BIOSOLIDS RESULTS**

| <b>SLUDGE RESULTS</b> |      | <b>05-Jan-17</b> | <b>02-Feb-17</b> | <b>02-Mar-17</b> | <b>06-Apr-17</b> | <b>04-May-17</b> | <b>01-Jun-17</b> | <b>06-Jul-17</b> | <b>03-Aug-17</b> | <b>07-Sep-17</b> | <b>05-Oct-17</b> | <b>02-Nov-17</b> | <b>12-Dec-17</b> |
|-----------------------|------|------------------|------------------|------------------|------------------|------------------|------------------|------------------|------------------|------------------|------------------|------------------|------------------|
| Ammonia               | mg/L | 565              | 853              | 508              | 191              | 333              | 65.5             | 16.9             | 8.91             | 2.9              | 0.27             | 0.1              | 32.9             |
| Nitrate               | mg/L | 1                | 0.5              | 0.2              | 17.3             | 1.9              | 23.5             | 161              | 270              | 274              | 332              | 322              | 177              |
| Ammonia + Nitrate     | mg/L | 566              | 854              | 508              | 208              | 335              | 89               | 178              | 279              | 277              | 332              | 322              | 210              |
| Total Phosphorus      | mg/L | 983              | 646              | 762              | 258              | 379              | 574              | 366              | 348              | 326              | 334              | 286              | 329              |
| Total Solids          | mg/L | 64100            | 18900            | 21700            | 10300            | 26200            | 17100            | 13900            | 11300            | 11800            | 11600            | 10200            | 11500            |
| Aluminum              | mg/L | 1390             | 881              | 894              | 453              | 386              | 704              | 586              | 555              | 530              | 525              | 472              | 408              |
| Arsenic               | mg/L | < 0.10           | < 0.10           | < 0.10           | < 0.01           | 0.30             | < 0.10           | 0.1              | < 0.1            | 0.2              | < 0.1            | 0.10             | < 0.10           |
| Cadmium               | mg/L | < 0.030          | < 0.030          | < 0.030          | < 0.030          | < 0.030          | < 0.030          | < 0.03           | < 0.3            | < 0.030          | < 0.03           | < 0.030          | < 0.030          |
| Chromium              | mg/L | 2.63             | 0.41             | 0.48             | 0.28             | 0.25             | 0.41             | 0.47             | 0.43             | 0.45             | 0.38             | 0.36             | 0.56             |
| Cobalt                | mg/L | 0.05             | 0.03             | 0.050            | 0.03             | < 0.03           | < 0.03           | 0.04             | 0.06             | 0.08             | 0.05             | 0.05             | 0.05             |
| Copper                | mg/L | 86.10            | 21.60            | 27.40            | 11.20            | 10.30            | 15.60            | 14.5             | 12.1             | 12.9             | 10.9             | 9.15             | 10.30            |
| Lead                  | mg/L | 1.80             | 0.60             | 0.60             | 0.30             | 0.30             | 0.40             | 0.7              | 0.3              | 0.4              | 0.3              | 0.30             | 0.40             |
| Mercury               | mg/L | 0.04             | 0.01             | 0.02             | 0.00             | 0.00             | 0.01             | 0.006            | 0.003            | 0.005            | 0.004            | 0.004            | 0.01             |
| Molybdenum            | mg/L | 0.37             | 0.15             | 0.19             | 0.09             | 0.08             | 0.14             | 0.13             | 0.1              | 0.14             | 0.11             | 0.09             | 0.09             |
| Nickel                | mg/L | 1.56             | 0.46             | 0.56             | 0.30             | 0.26             | 0.41             | 0.43             | 0.41             | 0.55             | 0.51             | 0.45             | 0.50             |
| Selenium              | mg/L | 0.10             | < 0.10           | < 0.10           | < 0.01           | < 0.10           | < 0.10           | < 0.1            | < 0.1            | < 0.1            | < 0.1            | < 0.10           | < 0.10           |
| Zinc                  | mg/L | 20.0             | 10.50            | 13.80            | 5.95             | 5.20             | 8.22             | 7.09             | 6.7              | 8.1              | 6.1              | 5.2              | 5.80             |

## 2017 - IROQUOIS WWTP MONTHLY AEROBIC BIOSOLIDS CONCENTRATION RATIO

|                   | Jan   | Feb   | Mar    | Apr   | May   | June  | July  | Aug   | Sept  | Oct   | Nov   | Dec   |
|-------------------|-------|-------|--------|-------|-------|-------|-------|-------|-------|-------|-------|-------|
| Ammonia           | 565   | 853   | 508.00 | 191   | 333.0 | 65.5  | 16.9  | 8.91  | 2.9   | 0     | 0     | 33    |
| Nitrate           | 1     | 0.5   | 0.20   | 17.3  | 1.9   | 23.5  | 161   | 270   | 274   | 332   | 322   | 177   |
| Ammonia + Nitrate | 566   | 854   | 508    | 208   | 335   | 89    | 178   | 279   | 277   | 332   | 322   | 210   |
| Total Phosphorus  | 983   | 646   | 762.00 | 258   | 379.0 | 574.0 | 366   | 348   | 326   | 334   | 286   | 329   |
| Total Solids      | 64100 | 18900 | 21700  | 10300 | 26200 | 17100 | 13900 | 11300 | 11800 | 11600 | 10200 | 11500 |
| Aluminum          | 1390  | 881   | 894.00 | 453   | 386.0 | 704.0 | 586   | 555   | 530   | 525   | 472   | 408   |
| Arsenic           | 0.1   | 0.1   | 0.1    | 0.0   | 0.3   | 0.1   | 0.1   | 0.1   | 0.2   | 0.1   | 0.1   | 0.1   |
| Cadmium           | 0.03  | 0.03  | 0.03   | 0.03  | 0.03  | 0.03  | 0.03  | 0.30  | 0.03  | 0.03  | 0.03  | 0.03  |
| Chromium          | 2.6   | 0.41  | 0.48   | 0.28  | 0.3   | 0.4   | 0.5   | 0.4   | 0.5   | 0.4   | 0.4   | 0.6   |
| Cobalt            | 0.05  | 0.03  | 0.05   | 0.03  | 0.03  | 0.03  | 0.04  | 0.06  | 0.08  | 0.05  | 0.05  | 0.05  |
| Copper            | 86.1  | 21.6  | 27.40  | 11.2  | 10.3  | 15.6  | 14.5  | 12.1  | 12.9  | 10.9  | 9.2   | 10.3  |
| Lead              | 1.8   | 0.6   | 0.60   | 0.3   | 0.3   | 0.4   | 0.7   | 0.3   | 0.4   | 0.3   | 0.3   | 0.4   |
| Mercury           | 0.037 | 0.010 | 0.02   | 0.003 | 0.004 | 0.007 | 0.006 | 0.003 | 0.005 | 0.004 | 0.004 | 0.009 |
| Molybdenum        | 0.4   | 0.15  | 0.19   | 0.09  | 0.1   | 0.1   | 0.1   | 0.1   | 0.1   | 0.1   | 0.1   | 0.1   |
| Nickel            | 1.6   | 0.46  | 0.56   | 0.3   | 0.3   | 0.4   | 0.4   | 0.4   | 0.6   | 0.5   | 0.5   | 0.5   |
| Selenium          | 0.1   | 0.1   | 0.10   | 0.01  | 0.1   | 0.1   | 0.1   | 0.1   | 0.1   | 0.1   | 0.1   | 0.1   |
| Zinc              | 20.0  | 10.5  | 13.80  | 5.95  | 5.2   | 8.2   | 7.1   | 6.7   | 8.1   | 6.1   | 5.2   | 5.8   |

Metals ratio = mg metals/kg solids

|            | Metal/Solids Ratio (Sludge) |      |      |      |       |      |      |       |       |      |      |      |             |
|------------|-----------------------------|------|------|------|-------|------|------|-------|-------|------|------|------|-------------|
|            | Jan                         | Feb  | Mar  | Apr  | May   | June | July | Aug   | Sept  | Oct  | Nov  | Dec  | Limit       |
| Arsenic    | 1.56                        | 5.29 | 4.61 | 0.97 | 11.45 | 5.85 | 7.19 | 8.85  | 16.95 | 8.62 | 9.80 | 8.70 | <b>170</b>  |
| Cadmium    | 0.47                        | 1.59 | 1.38 | 2.91 | 1.15  | 1.75 | 2.16 | 26.55 | 2.54  | 2.59 | 2.94 | 2.61 | <b>34</b>   |
| Chromium   | 41.0                        | 21.7 | 22.1 | 27.2 | 9.5   | 24.0 | 33.8 | 38.1  | 38.1  | 32.8 | 35.3 | 48.7 | <b>2800</b> |
| Cobalt     | 0.78                        | 1.59 | 2.30 | 2.91 | 1.15  | 1.75 | 2.88 | 5.31  | 6.78  | 4.31 | 4.90 | 4.35 | <b>340</b>  |
| Copper     | 1343                        | 1143 | 1263 | 1087 | 393   | 912  | 1043 | 1071  | 1093  | 940  | 897  | 896  | <b>1700</b> |
| Lead       | 28.1                        | 31.7 | 27.6 | 29.1 | 11.5  | 23.4 | 50.4 | 26.5  | 33.9  | 25.9 | 29.4 | 34.8 | <b>1100</b> |
| Mercury    | 0.58                        | 0.53 | 0.88 | 0.29 | 0.15  | 0.41 | 0.43 | 0.27  | 0.42  | 0.34 | 0.39 | 0.78 | <b>11</b>   |
| Molybdenum | 5.77                        | 7.94 | 8.76 | 8.74 | 3.05  | 8.19 | 9.35 | 8.85  | 11.86 | 9.48 | 8.82 | 7.83 | <b>94</b>   |
| Nickel     | 24.3                        | 24.3 | 25.8 | 29.1 | 9.9   | 24.0 | 30.9 | 36.3  | 46.6  | 44.0 | 44.1 | 43.5 | <b>420</b>  |
| Selenium   | 1.56                        | 5.29 | 4.61 | 0.97 | 3.82  | 5.85 | 7.19 | 8.85  | 8.47  | 8.62 | 9.80 | 8.70 | <b>34</b>   |
| Zinc       | 312                         | 556  | 636  | 578  | 198   | 481  | 510  | 593   | 686   | 526  | 505  | 504  | <b>4200</b> |

|                             |      |      |      |      |      |      |      |      |      |      |      |      |
|-----------------------------|------|------|------|------|------|------|------|------|------|------|------|------|
| <b>Sludge is Acceptable</b> | TRUE | TRUE | TRUE | TRUE | TRUE | TRUE | TRUE | TRUE | TRUE | TRUE | TRUE | TRUE |
|-----------------------------|------|------|------|------|------|------|------|------|------|------|------|------|

SOME ANALYSIS RESULTS EXPRESSED AS "<" (LESS THAN);HOWEVER, IN ORDER TO COMPLETE THE CALCULATION, ONLY THE NUMERIC VALUE WAS USED; THEREFORE THE AVG. CONC. IS GREATER THAN ACTUAL.

**APPENDIX B:**  
CALL-OUT SUMMARY

## **Iroquois WWTP Call-Outs**

- Jan 13:       -UV major alarm, 5 lamps out  
                  -Alarm acknowledged and reset, the bulbs were replaced
- April 5:       -ACV 701 failed to open, torque trip  
                  -Valve was opened and closed manually and the torque percentage was increased
- April 7:       - Pumping station high level alarm  
                  -Checked plant to ensure there was no bypass. Plant was keeping up with flows in Type 3  
                  -Bypass from 3:43am-4:28am  
                  -Samples were taken during bypass event and bypass was monitored until flows returned to normal  
                  -Contacted MOE
- April 8:       -ACV 701 failed to close, torque trip  
                  -Valve was opened and closed manually and the torque percentage was increased
- April 10:      -ACV 701 failed to close, torque trip  
                  -Valve was opened and closed manually and the torque percentage was increased
- April 13:      -SBR PLC lost communication due to loose wire  
                  -Tightened wire connections and communication to PLC was restored
- April 19:      -ABS 3 refused to run  
                  -ABS 3 was turned off and blowers ABS 1 & 2 ran for the night  
                  -Electrician looked at the blower the following day and ensured it reset
- June 24:      -UV major alarm due to banks tripped.  
                  -UV system was reset
- June 30:      -High flows/level in SBRs  
                  -High flows caused water to be diverted to the high rate tank  
                  -Plant was able to keep up with flows and water in high rate tank was pumped to the headworks the following day  
                  -ACV 702 failed to close, torque trip  
                  -Valve was opened and closed manually and the torque percentage was increased
- July 11:      -ACV 702 failed to close, torque trip  
                  -Valve was opened and closed manually and the torque percentage was increased

- July 22:       -ABG 1 high temp or pressure alarm  
                  -Blower reset as well as SBR HMI restarted
- July 24-25:    -High screen and SBR level alarm  
                  -High flows caused water to be diverted to the high rate tank  
                  -Plant was able to keep up with flows and water in high rate tank was  
                  pumped to the headworks the following day
- Aug 9:         -Headworks alarm; valve 404 refused to open and put into Type 3  
                  -Valve was put into local, SBR was decanted and then the SBR was halted  
                  -Rotork came at a later date and fixed the valve
- Aug 11:        -Hydraulic pump on UV cleaning mechanism fault  
                  -Hydraulic fluid was changed
- Aug 12:        -P3 VFD faulted  
                  -P3 VFD only needed to be reset
- Aug 23:        -Power Outage  
                  -Alarms caused by power outage were reset  
                  -UV blubs that went out due to power outage were replaced
- Oct 30:        -High level in wet well alarm  
                  -Samples were taken during bypass event and bypass was monitored until  
                  flows returned to normal  
                  -Contacted MOE

## **APPENDIX C:**

### **MAJOR MAINTENANCE PROJECT SUMMARY**

## **Iroquois WWTP Major Maintenance Projects Summary 2017**

|           |  |
|-----------|--|
| Jan 16:   | -Replaced UV bulbs   |
| Feb 1:    | -Replaced UV bulbs<br>-RDT on site for lift inspection                             |
| Feb 16:   | -Premier Tech reduced threshold in SBRs to start Type 3 to 5500m <sup>3</sup> /Day |
| Feb 27:   | -Replaced UV bulbs & ballast   |
| March 1:  | -Replaced UV bulbs   |
| March 22: | -MPS certifying backflow preventers  |
| March 28: | -Replaced UV bulbs   |
| April 20: | -ABS 3 reset switch fixed  |
| May 2:    | -Replaced UV bulbs   |
| May 11:   | -Replaced two UV ballasts<br>-Roads built berm around horseshoe driveway           |
| June 8:   | -Fire extinguisher inspection  |
| July 4:   | -Alum delivered  |
| July 7:   | -Replaced UV bulbs   |
| July 12:  | -Morrisburg Plumbing installed two washtubs and drains                             |
| July 14:  | -Eastern Welding installed railing   |
| July 19:  | -Kevin from Aerzen on site for blower maintenance & fixing ABG 1&2                 |
| July 27:  | -Rotork valve 404 that is seized being removed from Gilles from Rotork             |
| Aug 2:    | -Rotork on site to reinstall valve 404   |
| Aug 4:    | -Chubb Edwards on site to fix security system                                      |
| Aug 11:   | -Rotork on site to fix 4-20 signal wires   |
| Aug 18:   | -Replaced UV bulbs   |



Aug 24: -Replaced UV bulbs

Sept 1: -Replaced UV bulbs

Sept 21: -Replaced UV bulbs

Oct 2: -Replaced UV bulbs

Oct 27: -Replaced UV bulbs

Nov 1: -Dave Phifer looking at pump float control issue  
-Rob from QEL on site to calibrate gas detectors

Nov 6: -Dave Phifer replaced bad relay on float control system

Nov 9: -Alum delivered

Nov 23: -Rob from QEL on site to repair gas meter

Nov 27: -Replaced UV bulbs

Dec 11: -GenRep on site to do annual generator maintenance

## **APPENDIX D:**

### **INSTRUMENT CALIBRATIONS & VERIFICATIONS**

## **5 Iroquois WPCP.**

### **Site Reports July, 2017**

## 5.1 FIT-401 Waste Sludge Basin 1:

DTM Version: 3.13.00

Page 1/3

### Flowmeter Verification Certificate Transmitter

|                              |                             |
|------------------------------|-----------------------------|
| Customer                     | Plant                       |
| Order code                   | Taq Name                    |
| PROMAG 10 W DN80             | 1.0381 - 1.0381             |
| Device type                  | K-Factor                    |
| H107C816000                  | 0                           |
| Serial number                | Zero point                  |
| V1.03.00                     | Software Version I/O-Module |
| Software Version Transmitter | 10:48                       |
| 07/19/2017                   | Verification time           |
| Verification date            |                             |

### Verification result Transmitter: Passed

| Test item        | Result     | Applied Limits |
|------------------|------------|----------------|
| Amplifier        | Passed     | Basis: 0.65 %  |
| Current Output 1 | Passed     | 0.05 mA        |
| Pulse Output 1   | Not tested | 0 P            |
| Test Sensor      | Passed     |                |

|                           |                        |
|---------------------------|------------------------|
| <b>FieldCheck Details</b> | <b>Simubox Details</b> |
| 240223                    | 8784351                |
| Production number         | Production number      |
| 1.07.08                   | 1.00.01                |
| Software Version          | Software Version       |
| 06/2017                   | 09/2016                |
| Last Calibration Date     | Last Calibration Date  |

Date Operator's Sign Inspector's Sign

#### Overall results:

The achieved test results show that the instrument is completely functional, and the measuring results lie within +/- 1% of the original calibration. <sup>1)</sup>

The calibration of the Fieldcheck test system is fully traceable to national standards.

<sup>1)</sup> Prerequisite is an additional proof of electrode integrity with high voltage test.

## FieldCheck - Result Tab Transmitter

|                              |                  |                             |                 |
|------------------------------|------------------|-----------------------------|-----------------|
| Customer                     |                  | Plant                       |                 |
| Order code                   |                  | Tag Name                    |                 |
| Device type                  | PROMAG 10 W DN80 | K-Factor                    | 1.0381 - 1.0381 |
| Serial number                | H107C816000      | Zero point                  | 0               |
| Software Version Transmitter | V1.03.00         | Software Version I/O-Module |                 |
| Verification date            | 07/19/2017       | Verification time           | 10:48           |

Verification Flow end value ( 100 % ): 20.106 l/s  
Flow speed 4.00 m/s

| Passed / Failed | Test item               | Simul. Signal      | Limit Value         | Deviation             |
|-----------------|-------------------------|--------------------|---------------------|-----------------------|
|                 | <b>Test Transmitter</b> |                    |                     |                       |
| ✓               | Amplifier               | 1.005 l/s (5%)     | 1.60 %              | 0.51 %                |
| ✓               |                         | 2.011 l/s (10.0%)  | 1.10 %              | 0.17 %                |
| ✓               |                         | 10.053 l/s (50.0%) | 0.70 %              | 0.12 %                |
| ✓               |                         | 20.106 l/s (100%)  | 0.65 %              | 0.00 %                |
| ✓               | <b>Current Output 1</b> | 4.000 mA (0%)      | 0.05 mA             | 0.002 mA              |
| ✓               |                         | 4.800 mA (5%)      | 0.05 mA             | 0.000 mA              |
| ✓               |                         | 5.600 mA (10.0%)   | 0.05 mA             | 0.002 mA              |
| ✓               |                         | 12.000 mA (50.0%)  | 0.05 mA             | 0.003 mA              |
| ✓               |                         | 20.000 mA (100%)   | 0.05 mA             | 0.015 mA              |
| —               | <b>Pulse Output 1</b>   | —                  | —                   | —                     |
|                 |                         | <b>Start value</b> | <b>Limits range</b> | <b>Measured value</b> |
|                 | <b>Test Sensor</b>      |                    |                     |                       |
| ✓               | Coil Curr. Rise         | 50.000 ms          | 13.340..50.000 ms   | 43.281 ms             |
| ✓               | Coil Curr. Stability    |                    | —                   | —                     |

### Legend of symbols

|        |        |            |              |           |
|--------|--------|------------|--------------|-----------|
| ✓      | ✗      | —          | ?            | !         |
| Passed | Failed | not tested | not testable | Attention |

## FieldCheck: Parameters Transmitter

|                              |                  |                             |                 |
|------------------------------|------------------|-----------------------------|-----------------|
| Customer                     |                  | Plant                       |                 |
| Order code                   |                  | Tag Name                    |                 |
| Device type                  | PROMAG 10 W DN80 | K-Factor                    | 1.0381 - 1.0381 |
| Serial number                | H107C816000      | Zero point                  | 0               |
| Software Version Transmitter | V1.03.00         | Software Version I/O-Module |                 |
| Verification date            | 07/19/2017       | Verification time           | 10:48           |

| Current Output | Assign      | Current Range | Value 0 4mA      | Value 20 mA |  |  |
|----------------|-------------|---------------|------------------|-------------|--|--|
| Terminal 28/27 | VOLUME FLOW | 4-20 mA activ | 0.0 l/s          | 50.00 l/s   |  |  |
|                |             |               |                  |             |  |  |
| Pulse Output   | Assign      | Pulse Value   | Output signal    | Pulse width |  |  |
| Terminal 24/25 | VOLUME FLOW | 0.008 m3/P    | Passive/Positive | 100.01 ms   |  |  |
|                |             |               |                  |             |  |  |

Actual System Ident.

125.0

## 5.2 FIT-402 Waste Sludge Basin 2:

DTM Version: 3.13.00

Page 1/3

### Flowmeter Verification Certificate Transmitter

|                              |                             |
|------------------------------|-----------------------------|
| Customer                     | Plant                       |
| Order code                   | Taq Name                    |
| PROMAG 10 W DN80             | 0.9737 - 0.9737             |
| Device type                  | K-Factor                    |
| JA091316000                  | 0                           |
| Serial number                | Zero point                  |
| V1.04.00                     |                             |
| Software Version Transmitter | Software Version I/O-Module |
| 07/19/2017                   | 10:57                       |
| Verification date            | Verification time           |

### Verification result Transmitter: Passed

| Test item        | Result     | Applied Limits |
|------------------|------------|----------------|
| Amplifier        | Passed     | Basis: 0.65 %  |
| Current Output 1 | Passed     | 0.05 mA        |
| Pulse Output 1   | Not tested | 0 P            |
| Test Sensor      | Passed     |                |

|                           |                        |
|---------------------------|------------------------|
| <b>FieldCheck Details</b> | <b>Simubox Details</b> |
| 240223                    | 8784351                |
| Production number         | Production number      |
| 1.07.08                   | 1.00.01                |
| Software Version          | Software Version       |
| 06/2017                   | 09/2016                |
| Last Calibration Date     | Last Calibration Date  |

..... Date ..... Operator's Sign ..... Inspector's Sign .....

#### Overall results:

The achieved test results show that the instrument is completely functional, and the measuring results lie within +/- 1% of the original calibration. <sup>1)</sup>

The calibration of the Fieldcheck test system is fully traceable to national standards.

1) Prerequisite is an additional proof of electrode integrity with high voltage test.

## FieldCheck - Result Tab Transmitter

|                              |                  |                             |                 |
|------------------------------|------------------|-----------------------------|-----------------|
| Customer                     |                  | Plant                       |                 |
| Order code                   |                  | Tag Name                    |                 |
| Device type                  | PROMAG 10 W DN80 | K-Factor                    | 0.9737 - 0.9737 |
| Serial number                | JA091316000      | Zero point                  | 0               |
| Software Version Transmitter | V1.04.00         | Software Version I/O-Module |                 |
| Verification date            | 07/19/2017       | Verification time           | 10:57           |

Verification Flow end value ( 100 % ): 20.106 l/s

Flow speed 4.00 m/s

| Passed / Failed | Test item               | Simul. Signal      | Limit Value       | Deviation      |
|-----------------|-------------------------|--------------------|-------------------|----------------|
|                 | <b>Test Transmitter</b> |                    |                   |                |
| ✓               | Amplifier               | 1.005 l/s (5%)     | 1.60 %            | 0.36 %         |
| ✓               |                         | 2.011 l/s (10.0%)  | 1.10 %            | 0.01 %         |
| ✓               |                         | 10.053 l/s (50.0%) | 0.70 %            | 0.09 %         |
| ✓               |                         | 20.106 l/s (100%)  | 0.65 %            | 0.02 %         |
| ✓               | Current Output 1        | 4.000 mA (0%)      | 0.05 mA           | -0.004 mA      |
| ✓               |                         | 4.800 mA (5%)      | 0.05 mA           | -0.007 mA      |
| ✓               |                         | 5.600 mA (10.0%)   | 0.05 mA           | -0.008 mA      |
| ✓               |                         | 12.000 mA (50.0%)  | 0.05 mA           | -0.020 mA      |
| ✓               |                         | 20.000 mA (100%)   | 0.05 mA           | -0.026 mA      |
| —               | Pulse Output 1          | —                  | —                 | —              |
|                 |                         | Start value        | Limits range      | Measured value |
|                 | <b>Test Sensor</b>      |                    |                   |                |
| ✓               | Coil Curr. Rise         | 50.000 ms          | 13.340..50.000 ms | 42.891 ms      |
| ✓               | Coil Curr. Stability    |                    | —                 | —              |

### Legend of symbols

|        |        |            |              |           |
|--------|--------|------------|--------------|-----------|
| ✓      | ✗      | —          | ?            | !         |
| Passed | Failed | not tested | not testable | Attention |



## FieldCheck: Parameters Transmitter

|                              |                  |                             |                 |
|------------------------------|------------------|-----------------------------|-----------------|
| Customer                     |                  | Plant                       |                 |
| Order code                   |                  | Tag Name                    |                 |
| Device type                  | PROMAG 10 W DN80 | K-Factor                    | 0.9737 - 0.9737 |
| Serial number                | JA091316000      | Zero point                  | 0               |
| Software Version Transmitter | V1.04.00         | Software Version I/O-Module |                 |
| Verification date            | 07/19/2017       | Verification time           | 10:57           |

| Current Output | Assign      | Current Range | Value 0 4mA      | Value 20 mA |  |  |
|----------------|-------------|---------------|------------------|-------------|--|--|
| Terminal 26/27 | VOLUME FLOW | 4-20 mA activ | 0.0 l/s          | 50.00 l/s   |  |  |
|                |             |               |                  |             |  |  |
| Pulse Output   | Assign      | Pulse Value   | Output signal    | Pulse width |  |  |
| Terminal 24/25 | VOLUME FLOW | 0.008 m3/P    | Passive/Positive | 100.01 ms   |  |  |
|                |             |               |                  |             |  |  |

Actual System Ident.

127.0



## 5.4 FIT-306 Raw Sewage Influent Channel 2:

| <b>FIELD EQUIPMENT VERIFICATION / CALIBRATION REPORT</b>  |  |                  |   |   |  |   | DATE: July 21 / 2017 |                       |
|---|--|------------------|---|---|--|---|----------------------|-----------------------|
| DESCRIPTION: Iroquois WPCP Raw Sewage Influent Ch#2.  |  |                  | MODEL: OCM III Model: 7ML 1002-0AA05    |   | TAG: FIT-306                           |   |                      |                       |
| MANUFACTURER : Siemens  |  |                  | Serial # S/N. PDB/C0010053              |   |  |   |                      |                       |
| Client Name: Township of South Dundas.  |  |                  |   |   | Device Output Signal : 4.00 - 20.00 mA |   |                      |                       |
| INSTALLATION INSPECTION   |  |                  |   |   |  |   |                      |                       |
|   | DESCRIPTION  | FINDINGS         |   |   |  | COMMENTS  |                      |                       |
|   |  | OK               | FIXED                                   | N/A   | FAULTY                                 |   |                      |                       |
| GENERAL   |  |                  |   |   |  | Calibration by means of Simulating Channel Level  |                      |                       |
| 1   | TAGGING  |                  |   | X   |  | Milltronics OCM-III Configuration   |                      |                       |
| 2   |  |                  |   |   |  | Flume Type = Parshall Size = 12"  |                      |                       |
| MECHANICAL  |  |                  |   |   |  | P47- Blanking Distance = 61.01694 cm  |                      |                       |
| 3   | MOUNTING: check for proper fastening, etc.   | X                |   |   |  | P46 - Zero Head = 173.4538 cm   |                      |                       |
| 4   | ORIENTATION: check for proper angle, etc.)   | X                |   |   |  | P7 - Max. Head = 44.1699 cm   |                      |                       |
| 5   | POSITION: relative position to other components (ie. for proper flow, blanking distance), etc. | X                |   |   |  | P1 Linear Units = cm<br>Flow Units = l/s  |                      |                       |
| 6   |  |                  |   |   |  | Type = Flow Parshall Damping = 20%  |                      |                       |
| ELECTRICAL  |  |                  |   |   |  | Relay 1 = Off Relay 2 = Off Relay 2 = Off   |                      |                       |
| 7   |  | X                |   |   |  | Trending Configuration Sample at 60 min. Intervals  |                      |                       |
| 8   | WIRE TAGGING:<br>(exists and proper wire type)   | X                |   |   |  |   |                      |                       |
| 9   | QUALITY OF CONNECTIONS:  | X                |   |   |  |   |                      |                       |
| 10  | GROUNDING:   | X                |   |   |  |   |                      |                       |
| 11  | SHIELDING:<br>(check if grounded only at PLC end of wire)                                      | X                |   |   |  |   |                      |                       |
| 12  | CERTIFICATION CSA, ULC:  | X                |   |   |  |   |                      |                       |
| SET-UP/CALIBRATION  |  |                  |   |   |  |   |                      |                       |
| DIGITAL   |  | ADJUSTMENT USING |   | VERIFIED USING  |  | SETPOINT / RANGE  |                      |                       |
| 14  | SETPOINT ADJUSTMENT  | MECHANICAL TYPE  |   | Level Target  |  |   |                      |                       |
|   |  | ELECTRONIC TYPE  |   | Fluke 752 calibrator<br>S/N 8759025<br>Cal. Report# July 18, 2017 |  | 0 – 198.7 l/sec   |                      |                       |
| Configuration Parameters:   |  |                  | Calibration Data Test Tolerance: 15.00% |   |  |   |                      |                       |
|   |  |                  | Input Variable                          | Transmitter Var.  | Cal. Value                             | % Error   | Notes                |                       |
|   |  |                  |   |   |  |   |                      |                       |
|   |  |                  | FIT 306                                 | 19.05 cm  | 54.7 l/sec                             | 53.9 l/s  | .40%                 | Jig set at 7.5 inches |
|   |  |                  |   | 54.7  | 8.55 mA                                | 8.40 mA   | .93%                 |                       |
| NOTES:***Current calculated based on Display Variable 8.40 mA = ((54.7/198.7)*16) +4<br>Error (% Full Scale) = ((Measured Output - Calculated Variable) / Full Scale) * 100<br>= ((8.55 mA – 8.40 mA) / 16 mA ) * 100<br>= 0.93 % of full scale |  |                  |   |   |  | Checked By: <i>Tim Stewart</i><br>Cell: 613 325 9213<br>Email: tim.stewart@capitalcontrols.ca |                      |                       |



## 5.6 FIT-304 Raw Waste Water Flow:

| <b>FIELD EQUIPMENT VERIFICATION / CALIBRATION REPORT</b>   |  |                         |   |   |   |   |
|--|--|-------------------------|---|---|---|---|
| DESCRIPTION: Iroquois WPCP Raw Water Flow  |  |                         |   |   | MODEL: 7ME65204PJ132AA2   |   |
| MANUFACTURER : Siemens FM MAG 5100W  |  |                         |   |   | TAG: FIT-304  |   |
| Serial: 192102H243   |  |                         |   |   | DATE: July 21 2017  |   |
| Client Name: Township of South Stormont .  |  |                         |   |   | Device Output Signal : 4.00 - 20.00 mA  |   |
| <b>INSTALLATION INSPECTION</b>   |  |                         |   |   |   |   |
|  | <b>DESCRIPTION</b>   | <b>FINDINGS</b>         |   |   |   | <b>COMMENTS</b>   |
|  |  | OK                      | FIXED   | N/A   | FAULTY  |   |
| <b>GENERAL</b>   |  |                         |   |   |   |   |
| 1  | TAGGING  |                         |   | X   |   | Flow verification by coil verification and output measurement |
| 2  |  |                         |   |   |   |   |
| <b>MECHANICAL</b>  |  |                         |   |   |   |   |
|  | MOUNTING: Check for proper fastening, etc.   | X                       |   |   |   | Coil Resistance = 113.9 Ohms = passed                         |
| 4  | CELL: Check Operation / Slope, etc.)   | X                       |   |   |   |   |
| 5  | POSITION: Relative position to other components (ie. for proper flow, blanking distance), etc. | X                       |   |   |   |   |
| 6  | Cleaning: Check for Staining or Deposits, etc.)  |                         |   |   |   |   |
| <b>ELECTRICAL</b>  |  |                         |   |   |   |   |
| 7  |  | X                       |   |   |   |   |
| 8  | WIRE TAGGING: (exists and proper wire type)  | X                       |   |   |   |   |
| 9  | QUALITY OF CONNECTIONS:  | X                       |   |   |   |   |
| 10   | GROUNDING:   | X                       |   |   |   |   |
| 11   | SHIELDING: (check if grounded only at PLC end of wire)   | X                       |   |   |   |   |
| 12   | CERTIFICATION CSA, ULC:  | X                       |   |   |   |   |
| <b>SET-UP/CALIBRATION</b>  |  |                         |   |   |   |   |
| <b>DIGITAL</b>   |  | <b>ADJUSTMENT USING</b> |   | <b>VERIFIED USING</b>   |   | <b>SETPOINT / RANGE</b>                                       |
| 14   | SETPOINT ADJUSTMENT  | MECHANICAL TYPE         |   |   |   |   |
|  |  | ELECTRONIC TYPE         |   | Fluke 725 calibrator<br>S/N 8759025<br>Cal. Report# July 18, 2017 | 0.0 – 300.0 l/Sec = 4.00 to 20.00 mA  |   |
| <b>Configuration Parameters:</b>   |  |                         | <b>Calibration Data Test    Tolerance: 5.0%</b> |   |   |   |
|  |  | <i>Input Variable</i>   | <i>Output Variable</i>                          | <i>% Error</i>  | <i>Status</i>   | <i>Notes</i>  |
|  |  |                         |   |   |   |   |
|  |  |                         |   |   |   |   |
|  | FIT- 304   | 47 l/s                  | 6.43 mA   | 0.50%   | Passed  |   |
| NOTES:***Current calculated based on Display Variable 6.51 mA = ((47/300.0)*16) +4<br>Error (% Full Scale) = ((Measured Output - Calculated Variable) / Full Scale) * 100<br>= ((6.43 mA – 6.51 mA) / 16 mA )*100<br>= -0.50 % of full scale |  |                         |   |   | Checked By: <i>Tim Stewart</i><br>Cell: 613 325 9213<br>Email: tim.stewart@capitalcontrols.ca |   |

## 5.7 FIT-302 P.S Inlet Sewage Flow:

| <b>FIELD EQUIPMENT VERIFICATION / CALIBRATION REPORT</b>   |  |                  |                                       |                |   |   |
|--|--|------------------|---------------------------------------|----------------|---|---|
| DESCRIPTION: Iroquois WPCP Inlet Sewage Flow Elizabeth St. Pump Station  |  |                  |                                       |                | MODEL: 7ME65204PJ132AA2   | DATE: July 21 / 2017  |
| MANUFACTURER : Siemens FM MAG 6000W  |  |                  |                                       |                | Serial: N1D2087032  | TAG: FIT-302  |
| Client Name: Township of South Stormont .  |  |                  |                                       |                | Device Output Signal : 4.00 - 20.00 mA  |   |
| INSTALLATION INSPECTION  |  |                  |                                       |                |   |   |
|  | DESCRIPTION  | FINDINGS         |                                       |                |   | COMMENTS  |
|  |  | OK               | FIXED                                 | N/A            | FAULTY  |   |
| <b>GENERAL</b>   |  |                  |                                       |                |   |   |
| 1  | TAGGING  |                  |                                       | X              |   | Flow verification by coil verification and output measurement |
| 2  |  |                  |                                       |                |   |   |
| <b>MECHANICAL</b>  |  |                  |                                       |                |   |   |
|  | MOUNTING: Check for proper fastening, etc.   | X                |                                       |                |   | Coil Resistance = 99.8 Ohms = passed                          |
| 4  | CELL: Check Operation / Slope, etc.)   | X                |                                       |                |   |   |
| 5  | POSITION: Relative position to other components (ie. for proper flow, blanking distance), etc. | X                |                                       |                |   |   |
| 6  | Cleaning: Check for Staining or Deposits, etc.)  |                  |                                       |                |   |   |
| <b>ELECTRICAL</b>  |  |                  |                                       |                |   |   |
| 7  |  | X                |                                       |                |   |   |
| 8  | WIRE TAGGING:<br>(exists and proper wire type)   | X                |                                       |                |   |   |
| 9  | QUALITY OF CONNECTIONS:  | X                |                                       |                |   |   |
| 10   | GROUNDING:   | X                |                                       |                |   |   |
| 11   | SHIELDING:<br>(check if grounded only at PLC end of wire)                                      | X                |                                       |                |   |   |
| 12   | CERTIFICATION CSA, ULC:  | X                |                                       |                |   |   |
| 13   |  |                  |                                       |                |   |   |
| SET-UP/CALIBRATION   |  |                  |                                       |                |   |   |
| DIGITAL  |  | ADJUSTMENT USING |                                       | VERIFIED USING |   | SETPOINT / RANGE  |
| 14   | SETPOINT ADJUSTMENT  | MECHANICAL TYPE  |                                       |                |   |   |
|  |  | ELECTRONIC TYPE  |                                       |                | Fluke 725 calibrator<br>S/N 8759025<br>Cal. Report# July 18, 2017                             | 0.0 – 400.0 l/Sec = 4.00 to 20.00 mA                          |
| Configuration Parameters:  |  |                  | Calibration Data Test Tolerance: 5.0% |                |   |   |
|  |  | Input Variable   | Output Variable                       | % Error        | Status  | Notes   |
|  |  |                  |                                       |                |   |   |
|  | FIT-302  | 92 l/Sec         | 7.63mA                                | .31%           | Passed  |   |
|  |  |                  |                                       |                |   |   |
|  |  |                  |                                       |                |   |   |
| NOTES:***Current calculated based on Display Variable 7.68 mA = ((92/400)*16) +4<br>Error (% Full Scale) = ((Measured Output - Calculated Variable) / Full Scale) * 100<br>= ((7.63mA – 7.68 mA) / 16 mA ) * 100<br>= -.31 % of full scale |  |                  |                                       |                | Checked By: <i>Tim Stewart</i><br>Cell: 613 325 9213<br>Email: tim.stewart@capitalcontrols.ca |   |

## 5.8 FIT-301 Inlet Sewage Plant Pump Station Flow

| FIELD EQUIPMENT VERIFICATION / CALIBRATION REPORT                                   |  |                 |                                       |                 |   |  |  |              |  |
|---|--|-----------------|---------------------------------------|-----------------|---|--|--|--------------|--|
| DESCRIPTION: Iroquois Inlet Sewage Plant P.S Flow Sewage Flow                       |  |                 |                                       |                 |   | MODEL: 7ME69201AA101AA0                |  | TAG: FIT-301 |  |
| MANUFACTURER : Siemens FM MAG 6000  |  |                 |                                       |                 |   | Serial: N1D2087032                     |  |              |  |
| Client Name: Township of South Stormont .   |  |                 |                                       |                 |   | Device Output Signal : 4.00 - 20.00 mA |  |              |  |
| INSTALLATION INSPECTION   |  |                 |                                       |                 |   |  |  |              |  |
| DESCRIPTION   |  |                 | FINDINGS                              |                 |   |  | COMMENTS   |              |  |
|   |  |                 | OK                                    | FIXED           | N/A   | FAULTY                                 |  |              |  |
| GENERAL   |  |                 |                                       |                 |   |  |  |              |  |
| 1   | TAGGING  |                 |                                       |                 | X   |  | - Flow Verification by means of coil verification and output measurement |              |  |
| 2   |  |                 |                                       |                 |   |  |  |              |  |
| MECHANICAL  |  |                 |                                       |                 |   |  | Coil Resistance = 101.4 Ohms = passed                                    |              |  |
|   | MOUNTING: Check for proper fastening, etc.   |                 | X                                     |                 |   |  |  |              |  |
| 4   | CELL: Check Operation / Slope, etc.)   |                 | X                                     |                 |   |  |  |              |  |
| 5   | POSITION: Relative position to other components (ie. for proper flow, blanking distance), etc. |                 | X                                     |                 |   |  |  |              |  |
| 6   | Cleaning: Check for Staining or Deposits, etc.)  |                 |                                       |                 |   |  |  |              |  |
| ELECTRICAL  |  |                 |                                       |                 |   |  |  |              |  |
| 7   |  |                 | X                                     |                 |   |  |  |              |  |
| 8   | WIRE TAGGING:<br>(exists and proper wire type)   |                 | X                                     |                 |   |  |  |              |  |
| 9   | QUALITY OF CONNECTIONS:  |                 | X                                     |                 |   |  |  |              |  |
| 10  | GROUNDING:   |                 | X                                     |                 |   |  |  |              |  |
| 11  | SHIELDING:<br>(check if grounded only at PLC end of wire)                                      |                 | X                                     |                 |   |  |  |              |  |
| 12  | CERTIFICATION CSA, ULC:  |                 | X                                     |                 |   |  |  |              |  |
| SET-UP/CALIBRATION  |  |                 |                                       |                 |   |  |  |              |  |
| DIGITAL   |  |                 | ADJUSTMENT USING                      |                 | VERIFIED USING  |  | SETPOINT / RANGE   |              |  |
| 14  | SETPOINT ADJUSTMENT  | MECHANICAL TYPE |                                       |                 |   |  |  |              |  |
|   |  | ELECTRONIC TYPE |                                       |                 | Fluke 725 calibrator<br>S/N 8759025<br>Cal. Report# July 18, 2017 |  | 0.0 – 400.0 l/s = 4.00 to 20.00 mA                                       |              |  |
| Configuration Parameters:   |  |                 | Calibration Data Test Tolerance: 5.0% |                 |   |  |  |              |  |
|   |  |                 | Input Variable                        | Output Variable | % Error   | Status                                 | Notes  |              |  |
|   |  |                 |                                       |                 |   |  |  |              |  |
|   |  |                 |                                       |                 |   |  |  |              |  |
|   | FIT- 301   |                 | 47 l/s                                | 6.10 mA         | 1.38%   | Passed                                 |  |              |  |
|   |  |                 |                                       |                 |   |  |  |              |  |
|   |  |                 |                                       |                 |   |  |  |              |  |
| NOTES:***Current calculated based on Display Variable 5.88 mA = ((47/400)*16) +4    |  |                 |                                       |                 | Checked By: <i>Tim Stewart</i>                                    |  |  |              |  |
| Error (% Full Scale) = ((Measured Output - Calculated Variable) / Full Scale) * 100 |  |                 |                                       |                 | Cell: 613 325 9213  |  |  |              |  |
| = ((6.10 mA – 5.88 mA) / 16 mA ) * 100  |  |                 |                                       |                 | Email: tim.stewart@capitalcontrols.ca                             |  |  |              |  |
| = 1.38 % of full scale  |  |                 |                                       |                 |   |  |  |              |  |

## 5.9 FIT-501 U.V Inlet Channel Flow:

| <b>FIELD EQUIPMENT VERIFICATION / CALIBRATION REPORT</b>  |  |                         |   |                        |   |   |              |
|---|--|-------------------------|---|------------------------|---|---|--------------|
| DESCRIPTION: Iroquois U.V Inlet Channel Flow  |  |                         | MODEL: 7ME65201AA101AA0   |                        | TAG: FIT-501  |   |              |
| MANUFACTURER : Siemens FM MAG 6000  |  |                         | Serial: N1D2087032  |                        |   |   |              |
| Client Name: Township of South Stormont .   |  |                         | Device Output Signal : 4.00 - 20.00 mA                            |                        |   |   |              |
| <b>INSTALLATION INSPECTION</b>  |  |                         |   |                        |   |   |              |
|   | <b>DESCRIPTION</b>   | <b>FINDINGS</b>         |   |                        |   | <b>COMMENTS</b>   |              |
|   |  | OK                      | FIXED   | N/A                    | FAULTY  |   |              |
| <b>GENERAL</b>  |  |                         |   |                        |   |   |              |
| 1   | TAGGING  |                         |   | X                      |   | <b>Channel Configuration:</b>   |              |
| 2   |  |                         |   |                        |   | H = 0.868m  |              |
| <b>MECHANICAL</b>   |  |                         |   |                        |   |   |              |
|   | MOUNTING: Check for proper fastening, etc.   | X                       |   |                        |   | B = 0.900m  |              |
| 4   | CELL: Check Operation / Slope, etc.)   | X                       |   |                        |   | <b>Sensor Configuration:</b>  |              |
| 5   | POSITION: Relative position to other components (ie. for proper flow, blanking distance), etc. | X                       |   |                        |   | h <sub>Sensor</sub> = 0.000 m (at bottom)    h <sub>max</sub> = 0.868 (max level) |              |
| 6   | Cleaning: Check for Staining or Deposits, etc.)  |                         |   |                        |   | Velocity = Sensor#1    Mounting = 0.000m<br>Wedge Pos. Average = X1               |              |
| <b>ELECTRICAL</b>   |  |                         |   |                        |   |   |              |
| 7   |  | X                       |   |                        |   | <b>Analog Configuration:</b>  |              |
| 8   | WIRE TAGGING: (exists and proper wire type)  | X                       |   |                        |   | Channel 1 = 4 mA to 20 mA   |              |
| 9   | QUALITY OF CONNECTIONS:  | X                       |   |                        |   | <b>Communications:</b>  |              |
| 10  | GROUNDING:   | X                       |   |                        |   | Mask I/P = 255.255.255.0  |              |
| 11  | SHIELDING: (check if grounded only at PLC end of wire)   | X                       |   |                        |   | Remote I/P = 192.168.000.010  |              |
| 12  | CERTIFICATION CSA, ULC:  | X                       |   |                        |   | Gateway = 192.168.000.001   |              |
| <b>SET-UP/CALIBRATION</b>   |  |                         |   |                        |   |   |              |
| <b>DIGITAL</b>  |  | <b>ADJUSTMENT USING</b> |   | <b>VERIFIED USING</b>  |   | <b>SETPOINT / RANGE</b>   |              |
| 14  | SETPOINT ADJUSTMENT  | MECHANICAL TYPE         |   |                        |   |   |              |
|   |  | ELECTRONIC TYPE         | Fluke 725 calibrator<br>S/N 8759025<br>Cal. Report# July 18, 2017 |                        | 0 – 400.0 l/s = 4.00 to 20.00 mA  |   |              |
| <b>Configuration Parameters:</b>  |  |                         | <b>Calibration Data Test    Tolerance: 2%</b>                     |                        |   |   |              |
|   |  |                         | <i>Input Variable</i>   | <i>Output Variable</i> | <i>% Error</i>  | <i>Status</i>   | <i>Notes</i> |
|   | FIT- 501   | Velocity<br>0.249 m/s   | Area = .839 x .900<br>=.755m <sup>2</sup>                         | 188.1 l/Sec            | 11.69 mA  | 1.06%   | passed       |
|   |  |                         |   |                        |   |   |              |
|   |  |                         |   |                        |   |   |              |
|   |  |                         |   |                        |   |   |              |
| <b>NOTES:***Current calculated based on Display Variable 11.52 mA = ((188.1/400)*16) +4</b><br><b>Error (% Full Scale) = ((Measured Output - Calculated Variable) / Full Scale) * 100</b><br><b>= ((11.69 mA – 11.52 mA) / 16 mA ) * 100</b><br><b>= 1.06 % of full scale</b> |  |                         |   |                        | Checked By: <i>Tim Stewart</i><br>Cell: 613 325 9213<br>Email: tim.stewart@capitalcontrols.ca |   |              |