South Dundas Regional Drinking Water System

Waterworks # 220001012 System Category – Large Municipal Residential

Annual Report

Reporting Period of January 1st – December 31st 2021

Issued: February 18th 2022

Revision: 0

This report has been prepared to satisfy the annual reporting requirements in O. Reg. 170/03 Section 11 and Schedule 22

Table of Contents

Annual Report1
Report Availability1
Compliance Report Card1
System Process Description1
Raw Source1
Treatment1
Distribution2
Treatment Chemicals used during the reporting year2
Summary of Non-Compliance2
Adverse Water Quality Incidents2
Non-Compliance
Non-Compliance Identified in a Ministry Inspection2
Flows
Raw Water Flows
Raw Flows
Maximum Flow Rates3
Treated Water Flows4
Treated Flows4
Annual Total Flow Comparison4
Regulatory Sample Results Summary5
Microbiological Testing5
Operational Testing
Inorganic Parameters5
Schedule 15 Sampling:6
Organic Parameters
Additional Legislated Samples8
Major Maintenance Summary
WTRS Submission ConfirmationA

Report Availability

As the South Dundas Regional Drinking Water System is considered a large municipal residential system under O. Reg. 170/03, this report must be made available to the public. It can be found at the municipal office, located at 34 Ottawa Street, Morrisburg, Ontario and on the municipal website (www.southdundas.com).

Compliance Report Card

Compliance Event	# of Events
Ministry of Environment Inspections	1
Ministry of Labour Inspections	1
QEMS External Audit	1
AWQI's/BWA	1
Non-Compliance	1
Spills	0
Watermain Breaks	11

System Process Description

Raw Source

Water is drawn from the St. Lawrence River through a 450 mm diameter steel intake pipe equipped with a sodium hypochlorite feed system for zebra mussel control. The raw water intake crib is located off shore, south of the low lift building located at the base of Augusta Street in Morrisburg. Three vertical turbine pumps convey water from the low lift building to the water treatment plant located at 99 Augusta Street, Morrisburg.

Treatment

Inside the water treatment facility, water undergoes ultra-filtration through membrane cassettes (ZeeWeed membranes, manufactured by Zenon) which are housed in large concrete tanks. There are three concrete filter tanks, each of which contains two ultra-filtration cassettes. Each filter has a chemical clean and backwash system. They are each equipped with a turbidity analyzer and particle count meter. Three granular activated carbon (GAC) contactors provide taste and odour control. Sodium hypochlorite is used for disinfection. A multi-cell baffled clearwell provides chlorine contact time.

Distribution

Water is transported through an 11.5 km transmission main from Morrisburg to Iroquois. The water is re-chlorinated at a booster station in Iroquois. A steel elevated storage tank is located in each town. Each has a capacity of 945 m³. There are approximately 15 kilometers of water main in Morrisburg and approximately 12 kilometers in Iroquois. The watermains are composed of PVC, cast iron and ductile iron. The combination of clear wells, the reservoir and the elevated tanks provide for peak hour demands and fire flows.

Treatment Chemicals used during the reporting year

Chemical Name	Use	Supplier
Sodium Hypochlorite	Disinfection	Brenntag

Summary of Non-Compliance

Adverse Water Quality Incidents

Date	AWQI #	Location	Problem	Details	Corrective Action Taken
Aug 16/21	155081	Morrisburg Distribution	Loss of system pressure	While in VFD mode, Cabinet CP20 At Morrisburg WTP failed causing loss of pressure in the system	Installed program if CP20 fails, a HLP will stay on at 80% to keep system pressure. And a HLP will automatically come on in low pressure.

Non-Compliance

Legislation	requirement(s) system failed to meet	Date	Details	Corrective Action	Status
Report made along with AWQI.					

Non-Compliance Identified in a Ministry Inspection

Legislation	requirement(s) system failed to meet	Date(s)	Corrective Action	Status
		None to report.		

Flows

South Dundas' Drinking Water System is operating on average under half the rated capacity.

Raw Water Flows

Raw water flows are regulated under the Permit to Take Water (PTTW). Raw flow data for 2021 was submitted to the Ministry electronically under Permit #4362-AAKQNY. The submission confirmation can be found attached in Appendix A.

Raw Flows



Maximum Flow Rates



Max. Allowable Flow - PTTW

Treated Water Flows

Treated water flows are regulated under the Municipal Drinking Water Licence (MDWL).

Treated Flows

Rated Capacity - MDWL





Annual Total Flow Comparison

Regulatory Sample Results Summary

Microbiological Testing

	No. of Samples Collected	Range of E.Coli Results		Range of Total Coliform Results		Range of HPC Results	
		Min	Max	Min	Max	Min	Max
Raw Water	52	0	1	0	10	n/a	n/a
Treated Water	52	0	0	0	0	2	2
Distribution Water	157	0	0	0	0	2	2

Operational Testing

	No. of Samples	R	ange of Resul	ts
	Collected	Minimum	Average	Maximum
Turbidity (NTU) - RW	8760	N/A	0.35	10.00
Turbidity (NTU) - TW	8760	N/A	0.03	2.00
Turbidity (NTU) - Filt1	8760	N/A	0.02	1.00
Turbidity (NTU) - Filt2	8760	N/A	0.02	0.80
Turbidity (NTU) - Filt3	8760	N/A	0.03	0.88
Free Chlorine Residual (mg/L) - TW	8760	1.09	1.61	2.17
Free Chlorine Residual (mg/L) – Iroquois Booster	8760	0.57	1.03	5.00
Free Chlorine Residual, On-Line (mg/L) – DW	8760	0.34	1.25	1.89
Free Chlorine Residual, In-House (mg/L) - DW	156	0.71	N/A	1.53

NOTE: Spikes recorded by on-line instrumentation may result from air bubbles and various

maintenance/calibration activities. All spikes are reviewed for compliance with O. Reg. 170/03.

Inorganic Parameters

These parameters are tested as a requirement under O. Reg. 170/03. Sodium and Fluoride are required to be tested every 60 months. Nitrate and Nitrite are tested quarterly and metals are tested annually as required under O. Reg. 170/03. In the event any parameter exceeds half the maximum allowable concentration the parameter is required to be sampled quarterly.

- MAC = Maximum Allowable Concentration as per O. Reg. 169/03
- MDL = Below the laboratory detection level

	Sample Date/	Sampla Bacult	MAC	No. of Exc	eedances
	(yyyy/mm/dd)	Sample Result	IVIAC	MAC	1/2 MAC
Treated Water					
Antimony: Sb (ug/L) - TW	2021/03/01	0.1	6.0	No	No
Arsenic: As (ug/L) - TW	2021/03/01	0.7	10.0	No	No
Barium: Ba (ug/L) - TW	2021/03/01	18.0	1000.0	No	No
Boron: B (ug/L) - TW	2021/03/01	22.0	5000.0	No	No
Cadmium: Cd (ug/L) - TW	2021/03/01	<mdl 0.02<="" td=""><td>5.0</td><td>No</td><td>No</td></mdl>	5.0	No	No
Chromium: Cr (ug/L) - TW	2021/03/01	<mdl 2.0<="" td=""><td>50.0</td><td>No</td><td>No</td></mdl>	50.0	No	No
Mercury: Hg (ug/L) - TW	2021/03/01	<mdl 0.02<="" td=""><td>1.0</td><td>No</td><td>No</td></mdl>	1.0	No	No
Selenium: Se (ug/L) - TW	2021/03/01	<mdl 1.0<="" td=""><td>50.0</td><td>No</td><td>No</td></mdl>	50.0	No	No

South Dundas Regional DWS - 2021 Annual Report

Rev. 0	Issued: February 18 2022	Ра

ge | 6

	Sample Date/	Council a Document		No. of Exc	eedances
	(yyyy/mm/dd)	Sample Result	MAC	MAC	1/2 MAC
Uranium: U (ug/L) - TW	2021/03/01	0.38	20.0	No	No
Additional Inorganics					
Fluoride (mg/L) - TW	2021/03/01	0.1	1.5	No	No
Nitrite (mg/L) - TW	2021/01/11	<mdl 0.1<="" td=""><td>1.0</td><td>No</td><td>No</td></mdl>	1.0	No	No
Nitrite (mg/L) - TW	2021/04/07	<mdl 0.1<="" td=""><td>1.0</td><td>No</td><td>No</td></mdl>	1.0	No	No
Nitrite (mg/L) - TW	2021/07/12	<mdl 0.1<="" td=""><td>1.0</td><td>No</td><td>No</td></mdl>	1.0	No	No
Nitrite (mg/L) - TW	2021/10/04	<mdl 0.1<="" td=""><td>1.0</td><td>No</td><td>No</td></mdl>	1.0	No	No
Nitrate (mg/L) - TW	2021/01/11	0.3	10.0	No	No
Nitrate (mg/L) - TW	2021/04/07	0.3	10.0	No	No
Nitrate (mg/L) - TW	2021/07/12	0.2	10.0	No	No
Nitrate (mg/L) - TW	2021/10/04	0.1	10.0	No	No
Sodium: Na (mg/L) - TW	2021/03/01	17.5	20*	N/A	N/A

*There is no "MAC" for Sodium. The aesthetic objective for sodium in drinking water is 200 mg/L. The local Medical Officer of Health should be notified when the sodium concentration exceeds 20 mg/L so that this information may be communicated to local physicians for their use with patients on sodium restricted diets.

Schedule 15 Sampling:

The Schedule 15 Sampling is required under O. Reg. 170/03. This system is under a reduced sampling schedule. Lead samples due Winter 2022/2023. No plumbing samples were collected.

Distribution System	Number of Sampling	Number of Samples	Range o	f Results	MAC	Number of
Distribution system	Points	Number of Sumples	Minimum	Maximum	(ug/L)	Exceedances
Alkalinity (mg/L)	6	6	86	99	n/a	n/a
рН	6	6	7.73	8.09	n/a	n/a
Lead (ug/l)	3	3	0.04	0.16	10	0

Organic Parameters

These parameters are tested annually as a requirement under O. Reg. 170/03. In the event any parameter exceeds half the maximum allowable concentration the parameter is required to be sampled quarterly.

- MAC = Maximum Allowable Concentration as per O. Reg. 169/03
- MDL = Below the laboratory detection level

	Sample Date (ample (dd) Sample (Sample Result	MAC	Number of Exceedances	
	(yyyy/mm/dd)			MAC	1/2 MAC
Treated Water					
Alachlor (ug/L) - TW	2021/03/01	<mdl 0.3<="" td=""><td>5.0</td><td>No</td><td>No</td></mdl>	5.0	No	No
Atrazine + Metabolites (ug/L) - TW	2021/03/01	< 0.5	5.00	No	No
Azinphos-methyl (ug/L) - TW	2021/03/01	<mdl 1.0<="" td=""><td>20.0</td><td>No</td><td>No</td></mdl>	20.0	No	No
Benzene (ug/L) - TW	2021/03/01	<mdl 0.5<="" td=""><td>1.0</td><td>No</td><td>No</td></mdl>	1.0	No	No
Benzo(a)pyrene (ug/L) - TW	2021/03/01	<mdl 0.006<="" td=""><td>0.01</td><td>No</td><td>No</td></mdl>	0.01	No	No
Bromoxynil (ug/L) - TW	2021/03/01	<mdl 0.5<="" td=""><td>5.0</td><td>No</td><td>No</td></mdl>	5.0	No	No

Rev. 0	Issued: February 18 2022	Page 7

	Sample Date			Number of	
	(yyyy/mm/dd)	Sample Result	MAC	MAC	
Carbaryl (ug/L) - TW	2021/03/01	<mdi 3.0<="" td=""><td>90.0</td><td>No</td><td>No</td></mdi>	90.0	No	No
Carbofyr $(ug/L) - TW$	2021/03/01	<mdi 1.0<="" td=""><td>90.0</td><td>No</td><td>No</td></mdi>	90.0	No	No
Carbon Tetrachloride (ug/L) - TW	2021/03/01	<mdi 0.2<="" td=""><td>2.0</td><td>No</td><td>No</td></mdi>	2.0	No	No
(1000000000000000000000000000000000000	2021/03/01	<mdl 0.5<="" td=""><td>90.0</td><td>No</td><td>No</td></mdl>	90.0	No	No
Diazinon (ug/I) - TW	2021/03/01	<mdl 0.9<="" td=""><td>20.0</td><td>No</td><td>No</td></mdl>	20.0	No	No
Dicamba $(ug/L) - TW$	2021/03/01	<mdi 10.0<="" td=""><td>120.0</td><td>No</td><td>No</td></mdi>	120.0	No	No
1 2-Dichlorobenzene (ug/L) - TW	2021/03/01	<mdi 0.5<="" td=""><td>200.0</td><td>No</td><td>No</td></mdi>	200.0	No	No
1 4-Dichlorobenzene (ug/L) - TW	2021/03/01	<mdl 0.5<="" td=""><td>5.0</td><td>No</td><td>No</td></mdl>	5.0	No	No
1 2-Dichloroethane (ug/L) - TW	2021/03/01	<mdl 0.5<="" td=""><td>5.0</td><td>No</td><td>No</td></mdl>	5.0	No	No
1 1-Dichloroethylene (ug/L) - TW	2021/03/01	<mdl 0.5<="" td=""><td>14.0</td><td>No</td><td>No</td></mdl>	14.0	No	No
Dichloromethane (Methylene Chloride) (ug/L) -	2021/03/01		50.0	No	No
TW	2021/03/01	SMDE 5.0	50.0	NO	NO
2,4-Dichlorophenol (ug/L) - TW	2021/03/01	<mdl 0.2<="" td=""><td>900.0</td><td>No</td><td>No</td></mdl>	900.0	No	No
2,4-Dichlorophenoxy acetic acid (2,4-D) (ug/L) - TW	2021/03/01	<mdl 10.0<="" td=""><td>100.0</td><td>No</td><td>No</td></mdl>	100.0	No	No
Diclofop-methyl (ug/L) - TW	2021/03/01	<mdl 0.9<="" td=""><td>9.0</td><td>No</td><td>No</td></mdl>	9.0	No	No
Dimethoate (ug/L) - TW	2021/03/01	<mdl 1.0<="" td=""><td>20.0</td><td>No</td><td>No</td></mdl>	20.0	No	No
Diquat (ug/L) - TW	2021/03/01	<mdl 5.0<="" td=""><td>70.0</td><td>No</td><td>No</td></mdl>	70.0	No	No
Diuron (ug/L) - TW	2021/03/01	<mdl 5.0<="" td=""><td>150.0</td><td>No</td><td>No</td></mdl>	150.0	No	No
Glyphosate (ug/L) - TW	2021/03/01	<mdl 25.0<="" td=""><td>280.0</td><td>No</td><td>No</td></mdl>	280.0	No	No
Malathion (ug/L) - TW	2021/03/01	<mdl 5.0<="" td=""><td>190.0</td><td>No</td><td>No</td></mdl>	190.0	No	No
2-Methyl-4chlorophenoxyacetic Acid (MCPA) (ug/L) - TW	2021/03/01	< 10	100.00	No	No
Metolachlor (ug/L) - TW	2021/03/01	<mdl 3.0<="" td=""><td>50.0</td><td>No</td><td>No</td></mdl>	50.0	No	No
Metribuzin (ug/L) - TW	2021/03/01	<mdl 3.0<="" td=""><td>80.0</td><td>No</td><td>No</td></mdl>	80.0	No	No
Monochlorobenzene (Chlorobenzene) (ug/L) - TW	2021/03/01	<mdl 0.5<="" td=""><td>80.0</td><td>No</td><td>No</td></mdl>	80.0	No	No
Paraguat (ug/L) - TW	2021/03/01	<mdl 1.0<="" td=""><td>10.0</td><td>No</td><td>No</td></mdl>	10.0	No	No
PCB (ug/L) - TW	2021/03/01	<mdl 0.05<="" td=""><td>3.0</td><td>No</td><td>No</td></mdl>	3.0	No	No
Pentachlorophenol (ug/L) - TW	2021/03/01	<mdl 0.2<="" td=""><td>60.0</td><td>No</td><td>No</td></mdl>	60.0	No	No
Phorate (ug/L) - TW	2021/03/01	<mdl 0.3<="" td=""><td>2.0</td><td>No</td><td>No</td></mdl>	2.0	No	No
Picloram (ug/L) - TW	2021/03/01	<mdl 15.0<="" td=""><td>190.0</td><td>No</td><td>No</td></mdl>	190.0	No	No
Prometryne (ug/L) - TW	2021/03/01	<mdl 0.1<="" td=""><td>1.0</td><td>No</td><td>No</td></mdl>	1.0	No	No
Simazine (ug/L) - TW	2021/03/01	<mdl 0.5<="" td=""><td>10.0</td><td>No</td><td>No</td></mdl>	10.0	No	No
Terbufos (ug/L) - TW	2021/03/01	<mdl 0.5<="" td=""><td>1.0</td><td>No</td><td>No</td></mdl>	1.0	No	No
Tetrachloroethylene (ug/L) - TW	2021/03/01	<mdl 0.5<="" td=""><td>10.0</td><td>No</td><td>No</td></mdl>	10.0	No	No
2,3,4,6-Tetrachlorophenol (ug/L) - TW	2021/03/01	<mdl 0.2<="" td=""><td>100.0</td><td>No</td><td>No</td></mdl>	100.0	No	No
Triallate (ug/L) - TW	2021/03/01	<mdl 10.0<="" td=""><td>230.0</td><td>No</td><td>No</td></mdl>	230.0	No	No
Trichloroethylene (ug/L) - TW	2021/03/01	<mdl 0.5<="" td=""><td>5.0</td><td>No</td><td>No</td></mdl>	5.0	No	No
2,4,6-Trichlorophenol (ug/L) - TW	2021/03/01	<mdl 0.2<="" td=""><td>5.0</td><td>No</td><td>No</td></mdl>	5.0	No	No
Trifluralin (ug/L) - TW	2021/03/01	<mdl 0.5<="" td=""><td>45.0</td><td>No</td><td>No</td></mdl>	45.0	No	No
Vinyl Chloride (ug/L) - TW	2021/03/01	<mdl 0.2<="" td=""><td>1.0</td><td>No</td><td>No</td></mdl>	1.0	No	No

Distribution samples are tested quarterly for THM's and HAA's in accordance with O. Reg. 170/03.

	Year	Sample Result	MAC	Number of Exceedances	
				MAC	1/2 MAC
Distribution Water					
Trihalomethane (THM): Total (ug/L)	2021	27.25	100	No	No
Annual Average - DW	2021	57.25	100	NO	NU
Haloacetic Acid (HAA): Total (ug/L)	2021	12.0	<u>ە</u> م	No	No
Annual Average - DW	2021	12.0	80	INO	INU

Additional Legislated Samples

Document	Parameter	Limit (mg/L)	Result (mg/L)
MDWL # 165-101	Filter Backwash Supernatant Suspended Solids	Annual Average < 25	1.5

Major Maintenance Summary

Descript	Description				
-	Iroquois tower rehabilitation				
-	Morrisburg tower rehabilitation				
-	Lowlift Pump 2 maintenance				
-	Felker/HWY 31 valve repair				
-	Control Panel 01 rack 1 and 2 replaced				
-	SCADA upgrades				
-	Booster station panel view changed				
-	Yearly generator maintenance				
-	Flow testing on hydrants				
-	Hydrants colour coded				
-	Yearly flow meter and analyzer calibrations				
-	Yearly backflow preventer maintenance				

Appendix A

WTRS Submission Confirmation

Ontario 😵	environet	WTRS	Ministry of the Environment, Conservation and Parks
WT DATA USER PROFILE CO	ONTACT US HELP HOME	E LOGOUT	
Location: WTRS / WT DATA / Input	WT Record		WTRS-WT-008
	Water Taking D	ata submitted successfully.	
Confirmation:			
Thank you for submitting your water t	taking data online.		
Permit Number: 4362-AAKQNY Permit Holder: THE CORPORATION OF Received on:Feb 2, 2022 8:37 AM This confirmation indicates that your of specified on the Permit Number, assig	THE TOWNSHIP OF SOUTH DU data has been received by the 1 ned to the Permit Holder stated	JNDAS. Ministry,but should not be construed as acc d above.	ceptance of this data if it differs from that
	Print Confirmatio	on Return to Main Page	
			SOUTH2 DUNDAS2 2022/02/02
			version: v4.5.0.21 (build#: 22) Last modified: 2018/09/18
Ontario 🞯 This site main the Governmen	tained by t of Ontario		©2022 <u>Queen's Printer for Ontario</u>