

# Williamsburg Wastewater System

---

Waterworks # 120002013

## Annual Report

Prepared By The Municipality of South Dundas

Reporting Period of January 1<sup>st</sup> – December 31<sup>st</sup> 2024

Issued: March 3<sup>rd</sup>, 2025

Revision: 0

Operating Authority:



The Municipality of  
**SOUTH DUNDAS**

This report has been prepared to meet the requirements set out in:

Document	Document #	Issue Date	Issue Number
Facility ECA	3-0456-84-887	January 28, 1992	N/A
ECA for Municipal Sewage Collection System	165-W601	June 2, 2023	1.0

Table of Contents

1    Revision History ..... 3

2    Operations and Compliance Reliability Indices..... 3

3    Process Description ..... 3

4    Treatment Flows ..... 3

5    Raw Sewage Quality..... 5

6    Effluent Quality ..... 8

7    Operating Issues/Problems..... 9

8    Maintenance..... 9

9    Sludge Generation..... 10

10    Summary of Complaints ..... 10

Appendix A - Performance Assessment Report ..... 11

Appendix B - Details of Abnormal Sewage Discharge Events ..... 12

Appendix C - ECA Annual Report Requirements ..... 13

## 1 Revision History

Date	Rev#	Revisions	Revised By
March 03, 2024	0	Annual Report Issued	Chelsea Fletcher, PCT Municipality of South Dundas

## 2 Operations and Compliance Reliability Indices

Compliance Event	# of Events
Ministry of Environment Inspections	No MECP inspection in 2024.
Ministry of Labour Inspections	No MOL inspection in 2024.
Non-Compliance	No Non-compliance in 2024
Community Complaints	No community complaints in 2024.
Spills	No spills reported in 2024.
Overflows	No overflow events reported in 2024.
Bypass	No bypass events reported in 2024.
Sewer Main Blockages	No sewer main blockages in 2024.


## 3 Process Description

Williamsburg's wastewater system is owned and operated by the Municipality of South Dundas. It consists of a gravity fed collection system, two sewage pumping stations and a wastewater treatment lagoon. The two-cell facultative lagoon system is a Class I wastewater treatment system. Effluent from the lagoon is discharged annually to the McMartin Drain between March 15th and April 21st in accordance with the facility's Certificate of Approval.


## 4 Treatment Flows

The hydraulic flows reaching the sewage lagoons in 2024 averaged 251 m<sup>3</sup>/day which represents 65.5% of the 383 m<sup>3</sup>/day design capacity.

#### 4.1 Raw Flow (m3/d)




##### 4.1.1 Annual Comparison (m3)



#### 4.2 Discharge Flow

Discharge Period	Start Date	End Date	Volume Discharged (m3)
Annual Discharge	April 2 <sup>nd</sup> , 2024	April 9 <sup>th</sup> , 2024	55,510

### 4.3 Annual Comparison (m3)




### 4.4 Imported Waste/Sewage

There was no imported waste or sewage accepted at this facility in 2024.


## 5 Raw Sewage Quality

Current year minimum, maximum and averages are available in Appendix A – Performance Assessment Report.


### 5.1.1 BOD5 (mg/L)




### 5.1.2 5-year BOD5 (mg/L)




### 5.1.3 Total Suspended Solids (mg/L)




### 5.1.4 5-year Total Suspended Solids (mg/L)




### 5.1.5 Total Phosphorus (mg/L)




### 5.1.6 5-year Total Phosphorus (mg/L)



### 5.1.7 Total Kjeldahl Nitrogen (mg/L)



### 5.1.8 5-year Total Kjeldahl Nitrogen (mg/L)



## 5.2 Imported Waste Quality

There were no imported wastes accepted at this facility in the 2024 reporting period.

# 6 Effluent Quality

For the 2024 discharge period, there were no exceedances of the concentration limits outlined in the facility's Certificate of Approval. The results from the spring discharge can be found tabulated in the Performance Assessment Reports attached in Appendix A.

## 6.1 Effluent Quality Assurance and Control Measures Taken

This system is part of the Municipality of South Dundas. The Municipality's Compliance and Operational Services are delivered by Municipal staff that work to protect the community and public health. The systems are operated to meet compliance with applicable regulations. The system has comprehensive manuals detailing operations, maintenance, instrumentation, and emergency procedures. All procedures are treated as active documents and are updated as required.

The process is reviewed and maintained by certified operators. These operators complete in-house rounds and testing to monitor the process. All Sampling and analysis follow approved methods and protocols for sampling, analysis and recording as specified in the Ministry's Procedure F-10-1, "Procedures for Sampling and Analysis Requirements for Municipal and Private Sewage Treatment Works", the Ministry's publication, "Protocol for the Sampling and Analysis of Industrial/Municipal Wastewater" and the publication, "Standard Methods for the Examination of Water and Wastewater".

All final effluent samples collected during the reporting period to meet legislated sampling requirements are submitted to Caduceon Ottawa for analysis, with the exception of pH and temperature. Caduceon Ottawa has been deemed accredited by the Canadian Association for Laboratory Accreditation (CALA), meeting strict provincial guidelines including an extensive quality assurance/quality control program. By choosing this laboratory, the Municipality of South Dundas is ensuring appropriate control measures are undertaken during sample analysis. The pH and temperature parameters are analyzed in the field at the time of sample collection by certified operators, to ensure accuracy and precision of the results obtained.

South Dundas uses a data management system maintained by staff, which includes:

- SharePoint – Municipality of South Dundas Water/Wastewater Site.
  - This online database consolidates all operational data from a variety of sources including field data, online instrumentation, and electronic receipt of lab test results for reporting, tracking and analysis.

The operations team also has access to in-house Operational Compliance and Process Technicians (PCTs) to assist for emerging process issues. This aids in establishing additional control measures to ensure a quality effluent product.

Detailed sample results for raw sewage and final effluent can be requested from the operating authority.



## 6.2 Effluent Quality Summary

Parameter	April Result (mg/L)	Limit (mg/L)	Exceedance
BOD	3.0	30	No
Total Suspended Solids	28.0	30	No
Total Phosphorus	0.37	N/A	N/A
Total Ammonia Nitrogen	0.12	N/A	N/A
pH	7.16-8.05	N/A	N/A

## 7 Operating Issues/Problems

There were no operating issues in the 2024 reporting period.

### 7.1 Effluent Quality Non-Compliance Summary

Date	Exceedance of	Limit	Value	Corrective Action
No ECA limits were exceeded in 2024				

### 7.2 Summary of Abnormal Sewage Discharge Events

Abnormal Discharge Events include Bypass', Overflows, Diversions and Spills of Sewage. Summary Details are included in Appendix B.

### 7.3 Spills (Other than Sewage)

Date	Location	Details	Volume (m3)	Start Date and Time	End Date and Time
No spills to report on in 2024.					

## 8 Maintenance

Routine planned maintenance activities:

- Inspect, adjust and calibrate process control equipment to ensure proper operation of water distribution systems, pumps, chemical feeders, and all other equipment installed at the facilities.
- Carry out a routine maintenance program including greasing and oiling as specified in the lubrication schedule.
- Perform day-to-day maintenance duties to equipment including checking machinery and electrical equipment when required.
- Maintain an equipment inventory
- Maintain accurate records of work conducted, activities, and achievements.

Unplanned maintenance is conducted as required.

### 8.1 Normal Maintenance and Repairs

Maintenance/Repair
<ul style="list-style-type: none"> <li>- Wet wells cleaned every quarter</li> <li>- Annual generator load test</li> <li>- Sluice gate wheel repaired due to weather and age</li> </ul>

### 8.2 Emergency Maintenance and Repairs

Maintenance/Repair	Details
No emergency maintenance in 2024.	

### 8.3 Flow Meter Calibrations and Maintenance

Location	Date of Calibration	Additional Maintenance
FIT-01 Williamsburg SPS Flow	May 28 <sup>th</sup> 2024	None.

### 8.4 Authorized Alterations in Collection System

Alteration	Details	Significant Drinking Water Threat (Y/N)
No alterations were made in 2024.		

### 8.5 Notice of Modifications

Date	Process	Modification	Status
No modifications made in 2024.			

## 9 Sludge Generation

Sludge depth is monitored periodically across the lagoon, and plans for sludge removal are made as required for optimal operation of the wastewater system.

## 10 Summary of Complaints

Location	Date	Nature of Complaint	Actions Taken
No complaints in 2024.			

# Appendix A

## Appendix A - Performance Assessment Report

### MUNICIPALITY OF SOUTH DUNDAS PERFORMANCE ASSESSMENT REPORT

PROJECT:	WILLIAMSBURG SEWAGE					YEAR:	2024								
WORKS NUM.:	3-0456-84-887					WATER COURSE:	MCMARTIN DRAIN								
DESCRIPTION:	A TWO CELL LAGOON HAVING A TOTAL SURFACE AREA OF 7.1 HA					DESIGN CAPACITY:	383 m <sup>3</sup> /day								
MONTH	FLOWS				Discharge Duration (days)	BIOCHEMICAL O <sub>2</sub> DEMAND			SUSPENDED SOLIDS			PHOSPHORUS			TKN
	Total Flow m <sup>3</sup>	Avg Day Flow m <sup>3</sup>	Max Day Flow m <sup>3</sup>	Effluent Flow m <sup>3</sup>		Avg Raw BOD (mg/L)	Avg Eff BOD (mg/L)	Percent Removal	Avg Raw SS (mg/L)	Avg Eff SS (mg/L)	Percent Removal	Avg Raw PHOS. (mg/L)	Avg Eff PHOS. (mg/L)	Percent Removal	Avg Raw TKN
JAN	8581	277	389			180			105			3.67			38.2
FEB	8888	306	443			168			164			6.11			63.3
MAR	11167	360	572			141			125			4.32			45.0
APR	11643	388	594	55,510	6	105	3.0		98	28.0		3.45	0.37		32.0
MAY	8060	260	318			159			150			2.68			21.3
JUN	6882	223	317			196			155			5.46			50.3
JUL	6150	198	276			119			174			5.57			54.3
AUG	8281	267	492			257			190			6.10			54.8
SEPT	5452	182	242			112			125			3.40			34.3
OCT	4663	150	164			194			210			8.64			110.0
NOV	4737	158	181			142			168			5.72			52.5
DEC	6529	211	302			166			130			4.41			43.8
TOTAL	90,833			55,510	6										
AVG		249				162	3.0	98.1	150	28.0	81.3	4.96	0.37	92.5	50.0
MAX			594			257			210			8.64			
CRITERIA		383					30			30					
COMPLIANCE		YES					YES			YES					
COMMENTS:	PERCENT REMOVAL BASED ON 12 MONTHS OF RAW COMPOSITE SAMPLES														

### MUNICIPALITY OF SOUTH DUNDAS LAGOON PERFORMANCE ASSESSMENT REPORT

PROJECT:

WORKS NUM.:

DESCRIPTION:

WILLIAMSBURG LAGOON

3-0456-84-887

A TWO CELL LAGOON HAVING A TOTAL SURFACE AREA OF 7.1 HA

YEAR:

WATER COURSE:

DESIGN CAPACITY:

2024

MCMARTIN DRAIN

383 m³/day

Minimum 2x per Week Sample Collection	SAMPLE RESULTS	SPRING			55,510	m³
	DATE	02-Apr	04-Apr	09-Apr-24	Average	C of A Limit*
	BOD (mg/L)	3	3	3	3.0	30
	TSS (mg/L)	70	11	3	28.0	30
	TP (mg/L)	0.51	0.3	0.3	0.37	
	NH <sub>3</sub> (mg/L)	0.12	0.13	0.11	0.12	
	NO <sub>2</sub> (mg/L)	<0.05	<0.05	<0.05		
	NO <sub>3</sub> (mg/L)	0.16	0.14	0.06		
	TKN (mg/L)	2.3	1.3	1.3		
	S2- (mg/L)	<0.16	0.02	<0.01		

EFFLUENT FLOW	
DATE	Flow (m³/d)
02-Apr	Start
03-Apr	21,840
04-Apr	7,280
05-Apr	2,730
08-Apr	3,640
09-Apr	20,020

\*910 m3 per inch

pH	8.05	7.16	7.62
Temp	11.9	9	10.3
S2- (mg/L)	<0.16	0.02	<0.01
%	---	55.9	---
undissociated H2S	ND	0.0112	ND

### Event Details Summary

Date	Location	Details	Volume (m3)	Start Time	End Time	Duration (h)	Discharge Receiver	Disinfection Provided
No bypass's of Williamsburg Sewage Lagoon to report in 2024.								

Date	Location	Details	Volume (m3)	Start Time	End Time	Duration (h)	Discharge Receiver	Disinfection Provided
No facility overflows to report in 2024.								

Date	Location	Details	Volume (m3)	Start Time	End Time	Duration (h)	Discharge Receiver	Disinfection Provided
No collection overflows to report in 2024.								

Date	Location	Details	Volume (m3)	Start Time	End Time	Duration (h)	Discharge Receiver	Disinfection Provided
No spills of sewage to report in 2024.								

# Appendix C

## Appendix C - ECA Annual Report Requirements

Facility ECA # 3-0456-84-887	Section in Report
No section in the CofA references an annual report.	N/A

Collection ECA # # 165-W601 Schedule E	
4.6.3 If applicable, includes a summary of all required monitoring data along with an interpretation of the data and any conclusion drawn from the data evaluation about the need for future modifications to the Authorized System or system operations.	Operating Issues and Problems
4.6.4 Includes a summary of any operating problems encountered and corrective actions taken.	Operating Issues and Problems
4.6.5 Includes a summary of all calibration, maintenance, and repairs carried out on any major structure, Equipment, apparatus, mechanism, or thing forming part of the Municipal Sewage Collection System.	Maintenance
4.6.6 Includes a summary of any complaints related to the Sewage Works received during the reporting period and any steps taken to address the complaints.	Summary of Complaints
4.6.7 Includes a summary of all Alterations to the Authorized System within the reporting period that are authorized by this Approval including a list of Alterations that pose a Significant Drinking Water Threat.	Maintenance
4.6.8 Includes a summary of all Collection System Overflow(s) and Spill(s) of Sewage, including: a) Dates; b) Volumes and durations; c) If applicable, loadings for total suspended solids, BOD, total phosphorus, and total Kjeldahl nitrogen, and sampling results for E.coli; d) Disinfection, if any; and e) Any adverse impact(s) and any corrective actions, if applicable.	Operating Issues and Problems
4.6.9 Includes a summary of efforts made to reduce Collection System Overflows, Spills, STP Overflows, and/or STP Bypasses, including the following items, as applicable: a) A description of projects undertaken and completed in the Authorized System that result in overall overflow reduction or elimination including expenditures and proposed projects to eliminate overflows with estimated budget forecast for the year following that for which the report is submitted. b) Details of the establishment and maintenance of a PPCP, including a summary of project progresses compared to the PPCP's timelines. c) An assessment of the effectiveness of each action taken. d) An assessment of the ability to meet Procedure F-5-1 or Procedure F-5-5 objectives (as applicable) and if able to meet the objectives, an overview of next steps and estimated timelines to meet the objectives. e) Public reporting approach including proactive efforts.	Maintenance Operating Issues and Problems